

# 中山市珍家山污水处理有限公司运行情况记录表

2020年1月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	7.5783	143	10.2	20.7	0.32	53.5	/	652000	注： cod、 氨氮进 出水浓 度均为 企业自 测数据
2	7.0429	169	12.6	23	0.58	50.42	/		
3	7.6453	154	12.1	24.5	1.17	77.69	/		
4	7.5747	125	12	28.2	0.88	42.77	/		
5	7.5188	148	12.5	27.4	1.24	63.77	/		
6	7.8156	185	13.1	26.8	0.88	51.6	/		
7	7.8184	187	14.6	27.2	2.99	82.45	/		
8	8.59	219	11.7	26.1	2.59	38.37	/		
9	8.9791	169	12.9	26.6	2.47	78.57	/		
10	8.8965	188	10.1	23.9	2.35	89.9	/		
11	9.0713	179	14	25.8	2.68	65.09	/		
12	8.8711	160	14.4	24.3	2.01	86.65	/		
13	8.7083	157	15.1	24.3	1.93	54.76	/		
14	9.0491	162	14.4	23.8	2.64	75.09	/		
15	9.5417	187	15.2	23	2.44	89.79	/		
16	9.6588	189	11	21.4	0.9	78.23	/		
17	9.4158	168	13.4	22.2	1.53	94.77	/		
18	9.7353	129	12.1	23.4	1.32	105.01	/		
19	9.6743	171	14.3	22.6	1.6	65.32	/		
20	9.7341	177	13.9	22.4	0.97	73.67	/		
21	10.2535	138	14.4	19.5	1.22	103.96	/		
22	10.2813	115	13.3	18	0.28	53.18	/		
23	10.3338	108	11.1	17.4	1.81	64.86	/		
24	10.2919	112	13.1	17.8	1.94	52.58	/		
25	10.3265	113	10.5	15.7	0.75	98.25	/		
26	10.3568	121	11.4	12.6	0.7	57.88	/		
27	10.3543	97	10.8	12.9	0.44	61.72	/		
28	10.4615	111	10	11.5	0.51	84.98	/		
29	10.4249	99	10	12.6	0.28	56.54	/		
30	10.4134	90	10	16.4	0.74	47.27	/		
31	10.3984	94	10	18.1	1.78	48.08	/		
合计 (或加权 平均)	286.816	145	12.3	20.9	1.4	2146.72	/	652000	



# 中山市珍家山污水处理有限公司运行情况记录表

2020年2月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	9.8063	111	10	16.5	1.32	67.87	/	547749	注： cod、 氨氮进 出水浓 度均为 企业自 测数据
2	10.8867	115	10	17.9	2.42	54.65	/		
3	10.6974	127	12.4	19.7	2.77	41.42	/		
4	10.5193	104	10	15.6	0.87	48.91	/		
5	10.7417	100	10.2	15.2	1.53	44.18	/		
6	10.6299	124	13.2	15.2	1.43	28.03	/		
7	10.0795	180	14.2	17.2	2	15.64	/		
8	10.2156	147	10.3	17.3	0.44	50.43	/		
9	10.2546	197	11.2	17.7	0.71	14.55	/		
10	9.9901	140	9.3	18.1	0.97	31.59	/		
11	10.3248	85	10.4	18.4	1.2	0	/		
12	10.0847	100	10	17.4	0.99	32.71	/		
13	10.1087	131	10	14.1	0.65	14.99	/		
14	10.3266	125	10.5	12.3	0.34	25.33	/		
15	10.6557	202	10	10.7	0.31	46.59	/		
16	10.4365	154	14.7	12.4	0.58	27.85	/		
17	9.6812	152	12.4	18.8	0.65	48.19	/		
18	9.612	131	11.4	14.9	1.05	47.61	/		
19	8.7892	132	10	16	0.74	33.54	/		
20	8.3951	161	13.2	16.1	0.39	42.55	/		
21	8.9917	107	13.2	15.1	0.32	42.97	/		
22	9.28	137	10.2	16.1	0.42	41.45	/		
23	9.6324	138	10	15.9	0.43	25.42	/		
24	10.5541	142	10	17	1.36	44.66	/		
25	10.4981	117	10	17.6	0.97	32.46	/		
26	9.7397	165	10.5	19.3	1.32	43.24	/		
27	10.1038	148	11.3	22.9	2.44	85.79	/		
28	9.9854	148	17.4	22.5	0.77	64.22	/		
29	9.9451	121	13.8	26.7	3.05	90.76	/		
/	/	/	/	/	/	/	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	290.966	136	11.4	17	1.14	1187.6	/		





# 中山市珍家山污水处理有限公司运行情况记录表

2020年3月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.0248	132	13.1	24.5	1.87	89.24	/	669901	注： cod、 氨氮进 出水浓 度均为 企业自 测数据
2	10.0721	135	13	23.6	2.39	79.28	/		
3	9.9161	149	11.3	22.3	0.93	91.69	/		
4	9.9691	147	11.7	23.8	1.65	100.65	/		
5	9.9961	214	10.9	23	1.5	90.45	/		
6	10.0898	254	12.5	19.4	1.59	89.76	/		
7	10.4147	151	14.5	24.2	2.01	93.13	/		
8	10.0796	139	13.3	27	1.01	93.69	/		
9	9.9391	114	17.7	25.3	1.67	58.09	/		
10	10.3893	115	11.5	14.9	1.46	95.66	/		
11	10.1022	101	15	29.7	2.35	92.58	/		
12	10.1622	147	14.5	30.2	1.57	94.13	/		
13	10.0659	131	13.9	25.2	1	88.36	/		
14	10.205	108	13.5	25.1	1.08	90.97	/		
15	9.9784	124	13	27.2	0.69	91.08	/		
16	10.0444	92	13.6	24.2	0.34	55.41	/		
17	10.0766	133	15.1	26.9	1.42	88.51	/		
18	10.1268	147	13.8	23.1	0.49	89.7	/		
19	10.0596	180	13.8	23.6	0.64	88.42	/		
20	10.0934	118	14.1	23.3	1.15	91.73	/		
21	10.1006	121	13.7	19.8	0.52	91.36	/		
22	10.2319	177	12.9	22.7	0.73	60.67	/		
23	9.9461	164	13.4	22.4	0.61	58.32	/		
24	9.9083	153	12.1	19.5	0.14	58.15	/		
25	9.9875	201	11.5	19.7	0.2	85.32	/		
26	9.871	175	11.5	23.1	0.55	83.69	/		
27	9.894	157	16.7	24.7	1.8	85.46	/		
28	10.3281	106	16.5	17.1	0.79	44.52	/		
29	10.4105	94	13.5	19.9	0.11	31.07	/		
30	6.7206	121	13.7	15.9	0.17	49.67	/		
31	10.6949	124	11.5	16.6	0.93	53.41	/		
合计 (或加权 平均)	309.899	143	13.4	22.9	1.09	2454.17	/	669901	



# 中山市珍家山污水处理有限公司运行情况记录表

2020年4月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.4967	188	13.2	19.1	2.97	(吨)	/	599597	注： cod、 氨氮进 出水浓 度均为 企业自 测数据 。2020 年4月8 日1： 00至 6：00 我司因 进水水 质异常 停产。
2	10.1519	111	10.8	16.2	3.74	29.43	/		
3	10.081	308	14.3	19.8	3.13	51.55	/		
4	9.8608	88	16.2	19.6	2.03	58.78	/		
5	10.1344	83	16.4	19.6	0.93	43.02	/		
6	10.2695	90	13.8	13.7	0.13	76.77	/		
7	10.4724	62	15.7	17.9	3.19	33.45	/		
8	7.7777	137	12.7	15.3	2.35	74.83	/		
9	9.8357	127	14.6	18.6	3.29	29.16	/		
10	9.6208	122	11.3	13.6	2.77	78.72	/		
11	8.6969	123	14.3	21.8	1.63	25	/		
12	8.4837	132	13.9	21.5	2.84	54.63	/		
13	9.6063	117	11.8	17.6	0.6	47.59	/		
14	7.3684	164	10.1	20.1	0.46	35.88	/		
15	8.4133	134	17.5	21.1	0.85	39.1	/		
16	9.5037	145	11.7	21.2	1.43	11.42	/		
17	9.0274	164	11.6	22.1	1.66	90.7	/		
18	9.291	142	13.4	22.1	1.8	60.63	/		
19	9.4926	162	13.5	21.8	1	36.64	/		
20	9.3693	177	14.9	24.1	1.02	52.06	/		
21	9.2305	131	12.1	22.7	0.29	43.24	/		
22	9.7621	145	11.3	15.6	0.09	0	/		
23	10.1637	97	10.5	12.9	0.17	27.41	/		
24	10.9158	108	12.2	17.9	1.49	53.41	/		
25	11.0088	96	11.3	19.6	0.66	33.9	/		
26	10.9988	91	12.5	22.9	1.2	56.97	/		
27	10.5633	158	13.8	23.5	1.82	26.85	/		
28	10.6985	211	13.8	24.8	1.54	15.12	/		
29	10.5417	174	12.5	23.8	0.82	65.23	/		
30	10.6143	173	14.7	23	0.36	75.75	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	292.451	138	13.2	19.8	1.54	1327.24	/	599597	





# 中山市珍家山污水处理有限公司运行情况记录表

2020年5月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含 水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	10.6592	232	12.8	26.6	1.3	66.12	/	671773	注： cod、 氨氮进 出水浓 度均为 企业自 测数据
2	9.7603	182	16.7	23.9	1.11	43.54	/		
3	10.8473	124	11.7	24.5	0.52	27.33	/		
4	10.8964	199	11	24	1.16	61.8	/		
5	10.8166	220	10.7	23.2	0.37	73.28	/		
6	10.861	164	11.4	23	0.62	72.8	/		
7	10.4492	169	10.5	21.4	0.27	52.29	/		
8	10.6699	167	12.2	27.1	1.04	78.66	/		
9	9.9995	161	11.6	24.3	0.51	59.14	/		
10	9.7736	/	10.7	22.5	0.35	37.36	/		
11	10.597	228	16.2	22.7	1.45	49.88	/		
12	10.9185	/	10.5	15.7	0.25	65.91	/		
13	10.8811	152	11.5	16.8	0.56	61.16	/		
14	10.7176	90	10.6	19	1.19	23.76	/		
15	10.9082	65	12.3	18.5	0.87	61.55	/		
16	10.9551	121	12.1	21.6	1.77	49.24	/		
17	9.9102	115	12.1	25.7	1.11	50.59	/		
18	10.393	182	12.9	20.2	0.37	67.2	/		
19	10.9158	128	13.5	21.9	1.68	73.38	/		
20	10.265	105	14	24.6	0.64	46.87	/		
21	10.02	206	12.4	25	0.82	59.79	/		
22	10.1129	70	11.2	15.8	0.23	91.58	/		
23	9.972	86	14.2	15.7	0.17	54.61	/		
24	9.9621	169	10.1	20.2	1.38	62.86	/		
25	9.7806	204	10	18.2	0.1	56.4	/		
26	10.6421	224	12.1	14.6	0.08	58.18	/		
27	10.3288	107	10	13.9	0.07	64.45	/		
28	10.3165	83	11.1	17.9	0.43	45.64	/		
29	10.3932	124	10.2	18.7	1.06	54.5	/		
30	10.3865	113	11.7	16	0.45	75.01	/		
31	10.6737	124	11.2	22.5	2.59	59.3	/		
合计 (或加权 平均)	323.7829	149	11.9	20.8	0.797	1804.18		671773	



# 中山市珍家山污水处理有限公司运行情况记录表

2020年6月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.2474	147	11	18.9	0.5	87.37	/	654150	注： cod、 氨氮进 出水浓 度均为 企业自 测数据
2	10.8461	126	10	14.1	0.27	63.02	/		
3	10.8468	110	10	16.2	0.6	40.97	/		
4	10.9152	107	10	18.2	0.81	47.5	/		
5	10.8896	108	10	19.2	1.21	72.71	/		
6	10.93	99	12.3	14.4	0.65	46.42	/		
7	11.0234	75	10.6	11.7	0.1	56.73	/		
8	10.9656	101	10.1	15.1	0.65	17.15	/		
9	10.8686	201	10	13.2	1.19	48.5	/		
10	10.4841	104	10	21.8	1.4	61.6	/		
11	10.2531	175	10.2	19.8	0.73	26.92	/		
12	10.6438	182	12.3	20.6	1.91	40.05	/		
13	10.5305	127	13.4	20.2	1.71	0	/		
14	10.6899	106	13	19	1.42	0	/		
15	10.7042	108	10	17.9	0.68	0	/		
16	10.655	151	11.5	21.8	1.66	0	/		
17	10.0956	128	10.3	20.6	0.65	0	/		
18	9.3058	95	10	19	0.33	16.7	/		
19	8.9589	217	14	23.5	1.12	15.75	/		
20	9.6421	151	11.5	22.6	0.58	0	/		
21	9.5473	123	10.2	21.6	0.23	0	/		
22	9.6286	138	10	20.6	0.44	10.54	/		
23	9.5804	236	10	22.1	0.16	49.03	/		
24	9.7106	180	12	18.7	0.12	42.65	/		
25	9.737	249	10	26.6	0.65	14.68	/		
26	9.8523	261	11.8	23.7	0.85	45.86	/		
27	9.8066	215	10	22.5	0.3	71.18	/		
28	9.7687	165	10	26	0.31	54.02	/		
29	8.3993	98	10	25.4	1.38	31.92	/		
30	8.2316	113	10	23.6	0.82	43.6	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	303.758	146	10.8	19.8	0.786	1004.87	/	654150	





# 中山市珍家山污水处理有限公司运行情况记录表

2020年7月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.6072	141	11.8	20.5	1.02	22.3	/	631262	注：7月28日1:00-17:00；7月28日22:00至7月29日13:00；7月30日15:00至7月31日12:00停产。cod、氨氮进出水浓度均为企业自测数据
2	9.1519	121	13	23.9	1.41	31.32	/		
3	9.3209	132	12.1	22.3	0.75	30.43	/		
4	9.2541	147	11.4	22.2	0.79	53.75	/		
5	8.5847	142	10	19.5	0.43	45.26	/		
6	9.0457	120	12.4	18.5	0.65	43.33	/		
7	9.1765	115	11.8	19	1.11	47.04	/		
8	8.9936	104	10.5	21.1	1.4	29.48	/		
9	9.1175	88	10.5	19.8	1.12	38.55	/		
10	8.9247	111	15	21.2	1.3	57	/		
11	9.5115	116	15	19.2	3.11	26.52	/		
12	9.3979	164	15	23.1	2.11	29.32	/		
13	9.0629	125	17	20.4	1.58	40.01	/		
14	9.0657	138	15	18.8	0.01	41.6	/		
15	9.061	134	15	19.7	0.18	26.09	/		
16	9.1418	145	15	19.9	0.61	43.04	/		
17	9.1554	126	15	19.6	1.89	47.71	/		
18	9.0709	108	15	20.5	1.6	39.12	/		
19	9.1241	165	15	19.6	1.96	56.73	/		
20	8.9604	139	15	19.5	1.75	51.45	/		
21	9.0758	145	15	21	1.65	46.07	/		
22	7.9015	117	15	20.9	1.13	39.16	/		
23	8.3095	175	15	21.5	1.63	49.83	/		
24	8.5898	119	15	21.3	1.1	59.95	/		
25	8.8038	112	15	19.5	3.6	79.55	/		
26	7.316	86	15	17.7	1.6	39.02	/		
27	5.2328	145	15	23.1	3.89	81.24	/		
28	0.2595	/	/	/	/	42.47	/		
29	1.2385	209	15	21	5.23	0	/		
30	2.851	/	/	/	/	46.7	/		
31	0.8545	152	16	20.9	3.74	82.51	/		
合计 (或加权平均)	242.161	129	13.9	20.5	1.45	1366.55	/	631262	



# 中山市珍家山污水处理有限公司运行情况记录表

2020年8月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	2.5038	/	15	/	0.61	86.42	/	629236	注： cod、 氨氮进 出水浓 度均为 企业自 测数据
2	3.7845	/	15	/	0.24	49.99	/		
3	7.5978	/	15	/	0.15	41.34	/		
4	9.1113	/	15	/	0.14	39.98	/		
5	9.8524	119	15	8.3	0.1	37.37	/		
6	9.5984	76	15	7.62	0.04	12.74	/		
7	9.4702	97	15	13.6	0.06	24.47	/		
8	9.605	141	15	16.1	0.58	43.55	/		
9	9.4891	111	15	16.8	0.49	21.18	/		
10	10.2869	117	15	18.7	1.48	33.47	/		
11	10.0826	179	15	21.7	1.52	48.08	/		
12	9.9541	77	15	13.9	0.71	31.45	/		
13	10.7451	61	15	9.69	0.05	35.98	/		
14	10.9044	67	15	12.3	0.21	35.26	/		
15	10.8712	57	15	10.8	0.7	48.75	/		
16	10.7793	81	15	12.2	0.33	45.35	/		
17	10.7813	69	15	15.5	0.79	52.23	/		
18	10.6644	70	15	15.4	0.38	57.68	/		
19	10.5101	45	15	6.57	0.11	10.22	/		
20	10.8414	49	15	11.2	0.28	53.99	/		
21	10.59	85	19	15.2	0.62	60.38	/		
22	10.9704	78	15	16.2	0.65	34.5	/		
23	10.5328	78	20	18.3	1.01	16.69	/		
24	11.0687	93	15	15.6	0.34	38.81	/		
25	11.0251	108	15	21	0.73	29.28	/		
26	10.1236	92	15	16.6	0.15	35.98	/		
27	11.1046	109	15	18.3	0.6	38.83	/		
28	10.9977	155	16.5	19	1.04	36.09	/		
29	10.5541	97	15	19.2	1.65	19.49	/		
30	9.1959	97	16	15.9	1.61	27.42	/		
31	9.7093	96	15	15.9	0.53	20.05	/		
合计 (或加权 平均)	303.306	92.3	15.4	14.9	0.589	1167.02	/	629236	





# 中山市珍家山污水处理有限公司运行情况记录表

2020年9月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.9541	101	15	16.3	0.75	32.42	/	589638	注： cod、 氨氮进 出水浓 度均为 企业自 测数据
2	10.3068	102	15	17.7	1.24	52.52	/		
3	10.3587	114	15	18.6	1.2	41.45	/		
4	11.62	126	15	14.6	0.34	68.54	/		
5	11.9864	110	15	19.1	1.11	50.89	/		
6	11.2665	132	15	18.3	0.39	48.45	/		
7	11.912	101	15	17.6	0.14	37.78	/		
8	11.9433	151	15	8.95	0.09	44.35	/		
9	12.1833	76	15	12.3	0.07	36.81	/		
10	9.8657	86	15	16.1	0.09	37.8	/		
11	8.1188	127	15	19.5	0.21	11.37	/		
12	11.2758	117	15	12.2	0.63	19.38	/		
13	10.1095	75	15	7.65	0.15	17.58	/		
14	10.4586	62	15	6.15	0.13	0	/		
15	8.7871	51	15	6	0.08	10.17	/		
16	6.4734	104	15	5.98	0.01	18.43	/		
17	6.4333	131	15	11	0.06	42.11	/		
18	6.567	129	15	10.3	0.09	38.15	/		
19	8.5299	93	15	7.73	0.09	46.76	/		
20	6.6181	141	15	8.62	0.11	50.6	/		
21	8.8305	112	15	8.3	0.07	56.02	/		
22	8.9324	123	15	13.9	0.09	38.79	/		
23	9.2144	120	15	10.1	0.12	49.1	/		
24	7.5249	134	15	13.4	0.26	49.22	/		
25	8.7482	193	15	13	0.28	42.28	/		
26	10.3405	59	15	11.4	0.36	44.07	/		
27	10.6284	149	15	18.1	0.92	48.09	/		
28	8.9245	196	15	19.2	1.64	61.64	/		
29	9.6706	113	15	18.1	0.69	62.17	/		
30	11.0256	89	15	14.1	1.02	63.39	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	289.608	113	15	13.4	0.44	1220.33	/	589638	



# 中山市珍家山污水处理有限公司运行情况记录表

2020年10月

企业名称名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.9556	65	15	7.33	0.13	66.88	/		
2	11.2201	85	15	15.2	0.63	79.06	/		
3	11.5598	94	15	15.5	1.06	65.47	/		
4	11.2109	98	15	14.2	0.07	98.99	/		
5	11.749	99	15	9.1	0.02	91.6	/		
6	11.8401	77	15	13.8	0.26	89.87	/		
7	11.623	92	21	18.3	0.88	41.76	/		
8	11.5898	95	15	16.8	0.65	89.19	/		
9	11.9227	95	15	16.4	0.33	65.4	/		
10	12.0849	78	15	18.4	1.17	61.17	/		
11	11.8926	100	15	21.3	1.06	101.63	/		
12	11.7105	105	15	19.7	0.82	68.21	/		
13	11.6605	87	15	18.3	0.34	51.14	/		
14	11.8016	110	15	20.2	0.78	34.04	/		
15	11.5785	94	15	20.9	0.56	73.73	/		
16	11.614	76	15	20	0.63	46.14	/	640652	
17	11.5339	79	17	19.3	0.36	36.99	/		
18	11.983	72	15	20.7	0.56	60.19	/		
19	10.5091	125	15	24	1.35	75.24	/		
20	9.0067	98	15	18.6	0.65	59.33	/		
21	10.0403	90	15	19.8	0.52	72.56	/		
22	11.6694	93	15	18.5	0.5	75.07	/		
23	11.6946	90	15	16.7	0.06	74.12	/		
24	11.9692	105	15	16.8	0.41	52.26	/		
25	11.8156	90	15	16.9	1.22	45.7	/		
26	10.7917	90	15	20.8	1.48	34.6	/		
27	10.9353	89	15	20.9	0.96	32.38	/		
28	11.4317	94	15	12.8	0.49	45.89	/		
29	9.5903	84	15	15.5	0.14	30.47	/		
30	11.4693	92	19	21.5	1.02	50.73	/		
31	10.9348	111	15	20	1.43	39.56	/		
合计 (或加权平均)	351.389	91.9	15.4	17.7	0.662	1909.37	/	640652	

注：  
cod、  
氨氮进  
出水浓  
度均为  
企业自  
测数据





# 中山市珍家山污水处理有限公司运行情况记录表

2020年11月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.7793	116	23	20	0.81	17.33	/		
2	10.8687	107	15	21.6	0.74	39.95	/		
3	10.449	108	20	22.7	0.51	59.04	/		
4	11.3259	95	18.5	24.2	1.35	43.04	/		
5	12.1768	84	21.5	25	1.62	45.51	/		
6	12.0482	108	21	15.4	1.06	31.64	/		
7	11.9608	103	15.5	22.8	1.04	33.54	/		
8	10.5609	185	15	20.6	0.9	0	/		
9	11.9695	99	18.5	22.1	1.1	32.48	/		
10	11.6239	91	17	20.9	1.4	20.83	/		
11	11.4781	107	18	20.8	1	29.87	/		
12	11.2867	83	20.5	21	1.46	31.66	/		
13	8.6471	81	15	18.6	0.36	24.38	/		
14	10.5121	94	15	21.3	0.95	23.19	/		
15	11.6168	102	19.5	22.2	1.02	49.21	/		
16	12.0889	115	26.5	23.4	1.34	7.42	/	625508	
17	11.2405	116	19	23.7	1.33	28.59	/		
18	11.464	136	20.5	23.4	0.89	39.67	/		
19	11.135	113	15	25	0.81	36.48	/		
20	11.2645	140	23	24.9	0.84	43.12	/		
21	11.1858	120	16	24	0.13	36.99	/		
22	11.1956	127	16	24.5	0.17	55.65	/		
23	11.091	120	18.5	23	0.32	48.64	/		
24	8.0754	112	21	22.7	0.32	39.64	/		
25	6.2187	122	20	25.2	0.39	23.15	/		
26	10.9932	125	21	25.6	0.57	47.06	/		
27	10.6851	106	18.5	23.8	0.21	21.84	/		
28	10.6275	120	19	22.4	0.55	49.37	/		
29	10.7683	113	15	23.1	0.58	48.68	/		
30	10.77	102	15	24.3	0.59	57.76	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	326.107	111	18.6	22.6	0.837	1065.73	/	625508	注： cod、 氨氮进 出水浓 度均为 企业自 测数据



# 中山市珍家山污水处理有限公司运行情况记录表

## 2020年12月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.3755	134	15	22.9	0.93	46.22	/	619445	注：cod、氨氮进出水浓度均为企业自测数据
2	10.628	117	15	22.6	0.81	38.5	/		
3	10.0831	173	15	23.4	1.17	22.31	/		
4	11.0156	166	15	21	1.25	32.2	/		
5	10.6611	242	15	21.6	1.75	41.42	/		
6	11.2756	243	15	23	1.9	42.82	/		
7	11.1853	135	15	24.4	1.69	48.29	/		
8	10.9319	111	15	21	1.21	83.7	/		
9	11.1111	132	15	21.6	1.31	35.13	/		
10	11.3875	117	15	21.6	1.47	73.31	/		
11	10.7702	106	15	21.6	1.26	68.57	/		
12	10.8001	124	15	23.1	1.25	71.45	/		
13	10.6409	107	15	22.9	1.22	58.84	/		
14	10.4987	127	15	24.1	1.47	46.36	/		
15	9.4635	97	17	19.1	2	24.93	/		
16	10.1484	127	16.5	22.8	1.8	0	/		
17	10.0124	107	15	21.5	1	51.76	/		
18	10.5234	140	15	21.4	0.97	10.11	/		
19	10.2741	126	15	18.8	1.48	40.6	/		
20	11.2795	116	15	17.6	0.89	58.7	/		
21	10.3276	123	15	20.9	0.91	12.15	/		
22	10.4531	111	15	16.5	0.35	35.66	/		
23	9.9027	133	15	24.1	1.66	32.84	/		
24	10.4093	136	17	26.1	1.82	34.21	/		
25	9.1058	147	15	20.5	0.88	46.59	/		
26	10.0038	159	15	21.8	0.86	34.59	/		
27	8.7592	104	15	23.2	0.77	42.3	/		
28	9.7518	127	19.5	23.1	0.18	41.8	/		
29	9.8793	124	15	22.8	0.99	38.63	/		
30	10.357	150	15	25	0.81	73.49	/		
31	9.9563	136	15	23.6	1	62.71	/		
合计 (或加权平均)	321.972	136	15.3	22	1.2	1350.19	/	619445	

