

# 污水处理厂运行情况记录表

2021年1月(一期)

企业名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	9.5016	119	17	19.2	0.86	123.73	/	731291	注: cod、氨氮 进出水 浓度均 为企业 自测数 据
2	9.2504	112	15	16.6	0.65	0	/		
3	9.7928	126	15	16.4	0.42	89.09	/		
4	9.4984	103	15	16.2	0.31	108.64	/		
5	9.5408	131	15	12.5	0.76	86.05	/		
6	9.1552	189	15	18.3	0.09	0	/		
7	8.9632	177	15	19.8	0.42	79.91	/		
8	8.0872	255	15	18.7	0.3	0	/		
9	7.5952	208	15	21.1	1.13	110.32	/		
10	7.3344	157	15	18.5	0.66	0	/		
11	6.9024	203	15	23.2	0.3	92.44	/		
12	6.2944	217	15	22.2	0.13	0	/		
13	7.5944	164	15	24.5	0.11	88.29	/		
14	7.1448	174	15	22.3	0.1	0	/		
15	8.0968	185	15	19.9	0.62	104.73	/		
16	8.2848	211	15	21.1	0.44	0	/		
17	8.956	205	15	15.2	0.47	60.43	/		
18	8.9352	201	15	20.4	0.43	0	/		
19	8.068	156	15	19.8	0.14	85.34	/		
20	6.5504	152	15	19.7	0.09	0	/		
21	5.8744	185	15	20.6	0.28	0	/		
22	6.0672	213	15	24	0.25	0	/		
23	6.0304	383	15	23.1	0.18	78.23	/		
24	5.9944	197	15	21.2	0.1	0	/		
25	6.1896	206	15	20.2	0.04	86.53	/		
26	6.5328	202	15	21.3	0.13	0	/		
27	6.2728	176	22	20.7	0.17	116.79	/		
28	6.7384	205	15	18.7	0.39	0	/		
29	6.2992	186	15	19.3	0.3	75.12	/		
30	8.0112	161	15	17	0.13	0	/		
31	6.2704	211	15	18.8	0.11	84.46	/		
合计 (或加权 平均)	235.827	182	15.3	19.4	0.361	1470.1	/	731291	

# 污水处理厂运行情况记录表

2021年1月（二期）

企业单位名称(盖章)：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	9.496	112	15	17.4	0.98	0	/	722127	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	9.2248	270	15	17.7	0.63	98.6	/		
3	9.8016	114	15	15.5	0.11	0	/		
4	9.4928	126	15	15.3	0.26	0	/		
5	9.5456	172	15	15.2	0.51	0	/		
6	9.0984	141	15	18.6	0.18	78.47	/		
7	8.8416	227	15	20.6	0.32	0	/		
8	7.976	272	15	20	0.25	120.7	/		
9	7.4592	227	15	20.7	1.08	0	/		
10	7.1904	182	15	18	0.42	112.88	/		
11	6.7496	193	15	24.2	0.12	0	/		
12	6.1272	170	15	18.1	0.22	85.42	/		
13	7.4776	163	15	22.2	0.23	0	/		
14	6.9928	175	15	22.2	0.16	119.82	/		
15	7.992	155	15	17.8	0.23	0	/		
16	8.1808	193	15	20.5	0.34	76.55	/		
17	8.8896	156	15	14.9	0.33	0	/		
18	8.8632	221	15	20.6	0.12	86.21	/		
19	7.9576	168	15	19.3	0.17	0	/		
20	6.4056	162	15	18.8	0.1	63.3	/		
21	5.7336	182	15	17.6	0.13	113.43	/		
22	5.9392	163	15	21.3	0.26	81.1	/		
23	5.932	260	15	22.1	0.25	0	/		
24	5.8872	225	15	19.6	0.16	96.19	/		
25	6.0944	198	15	15.7	0.06	0	/		
26	6.444	200	15	17.9	0.18	88.21	/		
27	6.1704	160	15	17.1	0.11	0	/		
28	6.64	176	15	17.9	0.24	53.4	/		
29	6.1576	138	15	17.1	0.16	0	/		
30	7.9368	203	15	13.8	0.5	72.48	/		
31	6.1744	223	15	17	0.14	0	/		
合计 (或加权 平均)	232.872	183	15	18.4	0.305	1346.76	/	722127	



# 中山市污水处理厂运行情况记录表

## 2021年2月(一期)

企业单位名称 (盖章)：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	7.9688	265	15	15.9	0.09	94.05	/	664554	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	7.7816	194	15	17.2	0.03	0	/		
3	7.5192	142	15	14.9	0.08	71.66	/		
4	7.6064	156	15	19.9	0.05	0	/		
5	6.8008	291	15	20	0.18	86.16	/		
6	6.5208	209	15	16.6	0.22	0	/		
7	7.0376	181	5	19	0.17	63.22	/		
8	7.4744	168	0	22	0.05	0	/		
9	7.216	163	6	16	0.12	67.9	/		
10	8.888	143	17	8.68	0.34	0	/		
11	9.1944	134	4.5	11.4	0.13	80.1	/		
12	8.7128	95	9	13.4	0.17	0	/		
13	8.5184	90	1.5	14.9	0.13	111.76	/		
14	8.9728	59	3	17.1	0.24	0	/		
15	8.4656	150	11	11.4	0.08	85.7	/		
16	7.484	477	6	13.6	0.03	0	/		
17	7.6152	132	7	17.5	0.09	139.2	/		
18	8.1232	126	6.5	17.7	0.08	139.84	/		
19	7.852	164	7	19.4	0.07	130.02	/		
20	6.465	109	6.5	19	0.03	0	/		
21	6.0544	139	12	21.9	0.23	134.24	/		
22	6.368	139	4	21.2	0.05	0	/		
23	6.6648	137	6	22.2	0.08	132.59	/		
24	6.0232	148	7	20.6	0.09	0	/		
25	7.6272	168	8	20.5	0.05	113.6	/		
26	8.5152	189	6	18.8	0.08	0	/		
27	8.5392	130	15.5	17.3	0.08	123.69	/		
28	8.6728	133	11	17.4	0.08	0	/		
/	/	/	/	/	/	/	/		
/	/	/	/	/	/	/	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	214.682	163	8.91	17.1	0.113	1573.73	/	664554	

## 中山市污水处理厂运行情况记录表

### 2021年2月（二期）

企业单位名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	7.9136	224	15	17.4	0.18	0	/	656230	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	7.7184	192	15	15.2	0.02	95.87	/		
3	7.4456	166	15	13.2	0.07	0	/		
4	7.5144	156	15	18.6	0.02	76.07	/		
5	6.62	163	15	18	0.15	0	/		
6	6.3776	207	8	16.2	0.16	83.59	/		
7	6.9024	160	3.5	17.3	0.45	0	/		
8	7.3688	162	2	21.8	0.05	102.86	/		
9	7.0872	168	8.5	17.4	0.13	0	/		
10	8.8056	204	19	8.68	0.2	109.19	/		
11	9.1016	150	4.5	10.8	0.09	0	/		
12	8.6176	90	9	13.2	0.14	80.1	/		
13	8.3904	93	3	13.5	0.14	0	/		
14	8.876	124	5	18	0.24	90.66	/		
15	8.3408	143	9.5	14	0.05	0	/		
16	7.3464	97	5	12.1	0.01	118.73	/		
17	7.4952	213	6.5	12.2	0.07	0	/		
18	7.976	113	14	15.5	0.06	0	/		
19	7.7344	130	11	16.6	0.07	0	/		
20	6.376	112	8.5	17.8	0.01	132.96	/		
21	5.8992	170	13	20.8	0.16	0	/		
22	6.2232	139	2	19.6	0.06	82.95	/		
23	6.568	199	9	19.8	0.06	0	/		
24	5.9296	147	14	18.1	0.08	51.48	/		
25	7.624	161	13	16.2	0.05	0	/		
26	8.5232	245	3	18.1	0.06	124.61	/		
27	8.5528	99	15	15.2	0.08	0	/		
28	8.6648	100	10.5	16.4	0.08	91.85	/		
/	/	/	/	/	/	/	/		
/	/	/	/	/	/	/	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	211.993	154	9.69	15.9	0.105	1240.92	/	656230	



# 中山市污水处理厂运行情况记录表

## 2021年3月(一期)

企业单位名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.9344	124	3	16	0.09	86.34	/	738229	注: cod、氨氮 进出水 浓度均 为企业 自测数 据
2	8.6424	136	8.5	13.2	0.26	0	/		
3	8.6688	111	3	25.8	0.34	42.17	/		
4	8.596	124	8.5	16.3	0.18	0	/		
5	9.1856	110	10	20.3	0.18	69.76	/		
6	8.2096	290.5	9.5	17.2	0.14	0	/		
7	7.8384	185	5	13.7	0.13	89.71	/		
8	8.6456	141	4.5	14.7	0.04	0	/		
9	8.6936	160	6.5	16.6	0.09	87.34	/		
10	7.7824	182	2.5	15.2	0.08	0	/		
11	7.848	179	7	16.6	0.19	110.75	/		
12	8.1184	139	0	21.8	0.22	0	/		
13	7.628	145	9	17	0.15	102.1	/		
14	7.5392	170	10	14.1	0.01	0	/		
15	8.0056	124	6	17.9	0.12	105.01	/		
16	7.6808	149	2.5	16.8	0.1	0	/		
17	7.8464	147	1	17	0.12	104.55	/		
18	7.6824	147	4	18	0.1	0	/		
19	8.0432	170	8	22	0.14	108.02	/		
20	7.2624	225	4	24.1	0.07	0	/		
21	6.892	224	8	19.9	0.13	97.36	/		
22	6.712	212	4	22	0.13	0	/		
23	8.3912	172	2	19.5	0.15	128.23	/		
24	7.8512	181	2	19	0.16	0	/		
25	7.4736	137	16.5	19.2	0.3	123.5	/		
26	8.1152	153	19.5	17.5	0.36	0	/		
27	8.2064	160	10.5	22.8	0.12	78.51	/		
28	7.9168	191	8.5	19.8	0.52	0	/		
29	8.1488	171	12.5	20.1	0.29	126.78	/		
30	8.6192	134	9	20.1	0.28	0	/		
31	8.2464	132	10	19.9	0.39	109.75	/		
合计 (或加权 平均)	249.424	161	6.95	18.5	0.181	1569.88	/	738229	



## 污水处理厂运行情况记录表

### 2021年3月（二期）

企业名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.9464	115	5	17	0.18	0	/	728847	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	8.64	123	6	16.4	0.16	103.91	/		
3	8.6784	119	2	14.5	0.13	0	/		
4	8.644	161	8	15.6	0.09	107.65	/		
5	9.2392	102	9.5	15.3	0.15	0	/		
6	8.18	343	16	16.8	0.16	102	/		
7	7.7912	199	7.5	14.4	0.11	0	/		
8	8.5926	195	7	15.5	0.04	106.38	/		
9	8.592	126	2	15.2	0.1	0	/		
10	7.6488	213	2.5	15.3	0.08	112.57	/		
11	7.6968	161	9	15.8	0.12	0	/		
12	7.9752	177	1	19.4	0.18	56.38	/		
13	7.476	159	3.5	17.1	0.16	0	/		
14	7.38	178	12	16.7	0.01	65.03	/		
15	7.884	121	6.5	17.2	0.17	0	/		
16	7.5424	154	7.5	15.5	0.09	125.23	/		
17	7.704	135	1	16.1	0.1	0	/		
18	7.5168	127	3	16.2	0.15	90.53	/		
19	7.8928	191	7.5	18.2	0.13	0	/		
20	7.092	182	7	17.5	0.13	64.48	/		
21	6.712	170	7	17.9	0.11	0	/		
22	6.5296	228	6.5	14.8	0.22	106.83	/		
23	8.2608	157	3	22.2	0.13	0	/		
24	7.7	166	2.5	17	0.13	86.61	/		
25	7.3432	155	10.5	18.6	0.28	0	/		
26	8.0112	170	16	16.9	0.35	92.99	/		
27	8.1024	148	12.5	18.7	0.16	0	/		
28	7.8024	211	7	19.4	0.39	72.86	/		
29	8.0248	186	17	18.8	0.44	0	/		
30	8.5208	155	15.5	16.4	0.27	88.98	/		
31	8.1344	145	13	14.4	0.15	0	/		
合计 (或加权 平均)	246.254	166	7.57	16.8	0.163	1382.43	/	728847	



# 污水处理厂运行情况记录表

2021年4月(一期)

企业单位名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万吨)	COD(毫克/升)		氨氮(毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.3864	164	7.5	21.4	0.16	119.38	/	708713	注: cod、氨氮 进出水 浓度均 为企业 自测数 据
2	8.3816	132	7.5	24.3	0.16	0	/		
3	8.3408	185	7.5	19.4	0.18	121.87	/		
4	7.9928	126	15	19.3	0.19	0	/		
5	7.9272	112	7.5	15	0.15	117.58	/		
6	8.0848	203	7.5	20.6	0.22	0	/		
7	8.2896	136	7.5	18.2	0.21	86.82	/		
8	8.4392	105	7.5	15.7	0.16	0	/		
9	8.2288	156	6	16.3	0.18	84.85	/		
10	8.0256	143	3.5	17.8	0.17	0	/		
11	8.3712	170	22	17.2	0.22	93.67	/		
12	8.4368	232	10	17.7	0.21	0	/		
13	8.2088	156	7.5	19.1	0.66	0	/		
14	8.3184	170	7.5	19.6	0.31	0	/		
15	7.952	187	7.5	18.3	0.16	91.36	/		
16	8.4584	256	7.5	9.88	0.05	0	/		
17	7.7664	315	22.5	18.4	0.07	91.36	/		
18	8.2112	126	7.5	15	0.23	0	/		
19	7.9768	174	7.5	13.7	0.17	92.47	/		
20	8.0464	131	7.5	18.1	0.25	0	/		
21	7.7584	134	7.5	22	0.4	78.42	/		
22	7.7328	130	7.5	20.6	0.35	0	/		
23	7.9176	177	7.5	21.3	0.57	67.02	/		
24	8.024	77	7.5	15.5	0.61	98.9	/		
25	8.2664	138	7.5	19.8	0.28	118.01	/		
26	8.028	170	7.5	22.6	0.55	0	/		
27	7.7848	97	7.5	20.3	0.36	107.47	/		
28	7.8	119	7.5	22.4	0.24	0	/		
29	7.7392	149	16	19.4	0.2	66.68	/		
30	7.3968	248	7.5	18.7	0.16	0	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	242.291	161	8.9	18.6	0.26	1435.86	/	708713	

## 污水处理厂运行情况记录表

### 2021年4月（二期）

企业单位名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.2784	192	7.5	15.6	0.15	0	/	695152	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	8.2608	140	7.5	19.2	0.16	61.01	/		
3	8.2	205	7.5	17.2	0.14	0	/		
4	7.8168	118	7.5	16.8	0.14	104.9	/		
5	7.7384	108	7.5	15	0.21	0	/		
6	7.9048	115	7.5	15	0.16	118.18	/		
7	8.1096	126	7.5	16.3	0.17	0	/		
8	8.2944	151	7.5	18.3	0.17	116.64	/		
9	8.088	209	10	16.9	0.2	0	/		
10	7.8856	152	8	20	0.17	104.64	/		
11	8.2432	179	2.5	21	0.17	0	/		
12	8.3176	194	2	16.9	0.21	86.73	/		
13	8.0816	200	5.5	17.8	0.66	78.16	/		
14	8.192	121	7.5	15.6	0.33	66.42	/		
15	7.8	187	7.5	16.8	0.16	0	/		
16	8.3136	236	7.5	21.9	0.1	67.28	/		
17	7.5912	254	26.5	16.5	0.09	0	/		
18	8.0552	111	7.5	12.9	0.26	50.39	/		
19	7.82	133	7.5	12.2	0.14	0	/		
20	7.888	123	7.5	14.9	0.26	72.08	/		
21	7.576	205	7.5	18.6	0.36	0	/		
22	7.5664	113	7.5	17	0.35	82.1	/		
23	7.7528	153	7.5	20.6	0.57	0	/		
24	7.868	152	7.5	22	0.6	0	/		
25	8.1272	137	20.5	19.5	0.27	0	/		
26	7.9272	155	7.5	20.7	0.59	61.88	/		
27	7.652	203	7.5	17.8	0.37	0	/		
28	7.64	206	7.5	17	0.22	97.53	/		
29	7.5424	141	7.5	15.9	0.22	0	/		
30	7.124	178	7.5	17.2	0.16	74.22	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	237.655	163	8.22	17.5	0.258	1242.16	/	695152	



# 污水处理厂运行情况记录表

2021年5月(一期)

企业单位名称 (盖章)：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.0192	272	7.5	21.2	0.24	96.19	/	749835	2021年5月19日 7:40至 2021年5月19日 20:30, 供电局供电线维护, 全厂停电
2	7.836	97	7.5	19.8	0.32	0	/		
3	7.8936	137	7.5	20.4	0.2	86.44	/		
4	7.756	148	7.5	16.8	0.16	0	/		
5	7.7256	195	7.5	14.4	0.15	84.18	/		
6	7.9544	113	7.5	17.6	0.19	0	/		
7	8.0784	148	7.5	21.4	0.13	69.46	/		
8	7.7832	136	7.5	21.5	0.2	49.23	/		
9	7.9448	157	7.5	23	0.21	95.83	/		
10	8.0392	162	7.5	22.8	0.38	0	/		
11	7.9584	149	7.5	22.8	0.8	85.45	/		
12	8.1888	156	7.5	21.7	0.44	0	/		
13	7.8896	178	7.5	21.4	0.58	100.44	/		
14	8.2632	143	7.5	18.6	0.3	0	/		
15	8.1232	144	7.5	19.7	0.21	73.52	/		
16	8.004	228	7.5	23.8	0.4	0	/		
17	7.792	211	7.5	23.2	0.87	50.49	/		
18	8.6456	0	0	0	0	0	/		
19	3.1168	179	0	24.2	0	30.26	/		
20	4.9048	163	7.5	22.8	0.23	0	/		
21	8.7712	110	7.5	14.7	0.65	119.77	/		
22	8.5552	185	16	26.5	0.46	0	/		
23	8.5288	174	7.5	21.3	0.38	69.28	/		
24	8.1064	340	22	20.4	0.84	0	/		
25	8.4728	174	7.5	9.3	0.15	85.9	/		
26	8.1946	149	7.5	16.5	0.1	0	/		
27	7.4582	122	7.5	16.3	0.07	106.22	/		
28	8.3128	244	7.5	20.2	0.67	0	/		
29	8.5256	191	7.5	17.9	0.46	106.58	/		
30	8.6216	133	18	18.5	0.25	0	/		
31	8.5016	356	7.5	18.4	0.31	74.16	/		
合计 (或加权平均)	243.9656	177	8.71	19.8	0.36	1383.4	/	749835	

# 污水处理厂运行情况记录表

2021年5月（二期）

企业单位名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万吨)	COD(毫克/升)		氨氮(毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	7.7656	138	7.5	18.8	0.24	0	/	729345 2021年5月19日 7:40至 2021年5月19日 20: 30, 供电局供电线维护, 全厂停电	
2	7.588	116	7.5	18.2	0.32	121.65	/		
3	7.6352	171	7.5	17.8	0.2	0	/		
4	7.5016	231	7.5	17.4	0.15	66.3	/		
5	7.4616	157	7.5	18.9	0.09	0	/		
6	7.692	98	7.5	14.6	0.18	118.32	/		
7	7.8512	163	20	22.1	0.12	0	/		
8	7.568	146	7.5	21.6	0.16	0	/		
9	7.7304	162	7.5	20.3	0.25	0	/		
10	7.824	176	7.5	20.4	0.37	54.65	/		
11	7.75	172	7.5	19.2	0.68	0	/		
12	8.0592	203	7.5	20	0.39	100.26	/		
13	7.7696	222	7.5	19.6	0.6	0	/		
14	8.152	169	7.5	16.4	0.2	78.04	/		
15	8.0232	145	7.5	20.2	0.21	0	/		
16	7.8968	136	7.5	19.5	0.39	83.37	/		
17	7.6832	224	7.5	24	0.86	0	/		
18	8.5376	0	0	0	0	87.97	/		
19	3.0424	220	0	27.2	0	0	/		
20	4.6472	192	7.5	24.8	0.24	79.39	/		
21	8.6	0	7.5	0	0.61	0	/		
22	8.348	194	7.5	27.5	0.44	102.16	/		
23	8.3448	151	7.5	21.8	0.39	0	/		
24	7.888	676	18	21.6	0.82	118.41	/		
25	8.2616	142	7.5	10.1	0.14	0	/		
26	8.012	172	7.5	19.8	0.12	96.74	/		
27	7.232	145	7.5	18.8	0.07	0	/		
28	7.6784	236	7.5	20.6	0.67	75.24	/		
29	8.224	215	7.5	17.1	0.4	0	/		
30	8.3376	122	7.5	16.9	0.24	81.47	/		
31	8.1936	208	7.5	16.4	0.26	0	/		
合计 (或加权平均)	237.2988	189	8.3	19.5	0.341	1263.97	/	729345	



# 污水处理厂运行情况记录表

2021年6月(一期)

企业名称名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.4496	187.33	7.5	10.9	0.25	98.54	/	743749	注: cod 、氨氮 进出水 浓度均 为企业 自测数 据
2	8.4632	103	7.5	8.52	0.08	0	/		
3	8.5728	96.57	7.5	14.3	0.11	70.89	/		
4	8.6696	144	7.5	9.48	0.03	0	/		
5	8.576	93	7.5	12.4	0.09	83.03	/		
6	8.66	124	7.5	14.9	0.12	0	/		
7	7.8056	140	7.5	18.2	1.02	86.89	/		
8	6.3584	133.71	7.5	19.1	0.25	0	/		
9	7.4364	164	7.5	18.5	0.57	90.99	/		
10	8.3688	118	7.5	19.5	1.19	0	/		
11	8.7069	134	22	19.6	0.49	0	/		
12	8.8627	127	26	15.5	0.37	0	/		
13	8.553	172.18	7.5	12.4	0.1	0	/		
14	8.7	146	7.5	10.6	0.1	0	/		
15	8.6416	72.68	7.5	10	0.1	0	/		
16	8.5368	78	7.5	15	0.06	0	/		
17	8.9024	146	7.5	16.5	0.07	0	/		
18	8.2232	166	7.5	16.8	0.1	0	/		
19	8.36	139	7.5	17.1	0.33	45.7	/		
20	9.0488	174	7.5	17.5	0.57	0	/		
21	9.1512	206	7.5	14.4	0.13	0	/		
22	9.328	121	7.5	7.32	0.08	0	/		
23	9.5792	103	7.5	6.41	0.04	169.67	/		
24	9.6504	93	7.5	5.48	0.04	0	/		
25	9.8	97	7.5	10.4	0.02	177.96	/		
26	9.6392	128.2	7.5	12.4	0.05	0	/		
27	9.3712	199	7.5	13.1	0.05	176.89	/		
28	8.792	162	7.5	14.4	0.21	0	/		
29	8.3712	175	7.5	15	0.5	177.55	/		
30	8.1816	187	7.5	14.4	0.39	0	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	259.76	137	8.62	13.5	0.241	1178.11	/	743749	

## 污水处理厂运行情况记录表

### 2021年6月（二期）

企业单位名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.1008	206	7.5	11.4	0.2	0	/	710101	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	8.2336	84	7.5	7.05	0.1	82.02	/		
3	8.3696	124	7.5	13.7	0.09	0	/		
4	8.4528	300	7.5	12.2	0.04	91.56	/		
5	8.3496	204	7.5	14.2	0.08	0	/		
6	8.4552	149	7.5	18	0.12	79.75	/		
7	7.6056	196	7.5	20.9	0.83	0	/		
8	6.0968	214.83	21	24.8	0.27	101.24	/		
9	7.1792	240	17	20.6	0.57	0	/		
10	8.1816	188	17	19	1.16	120.28	/		
11	8.528	260	7.5	18.2	0.42	135.37	/		
12	8.6728	186	7.5	15	0.36	163.11	/		
13	8.36	179.47	7.5	10.8	0.08	150.06	/		
14	8.4976	185	16	15.9	0.12	154.33	/		
15	8.4296	172	7.5	11.7	0.12	138.33	/		
16	8.1928	171	7.5	15.6	0.06	118.14	/		
17	8.352	210	7.5	14.3	0.07	34.38	/		
18	7.6528	226	7.5	17.1	0.08	11.9	/		
19	7.744	165	7.5	17.2	0.37	0	/		
20	9.1024	164	7.5	18.9	0.6	164.42	/		
21	8.3448	240	7.5	14.8	0.12	143.41	/		
22	8.708	176	7.5	7.5	0.08	153.67	/		
23	8.8048	179	7.5	8.27	0.04	0	/		
24	8.8776	176	16	6.51	0.03	178.12	/		
25	9.3296	128	7.5	10.4	0.03	0	/		
26	9.2464	145.12	7.5	10.8	0.05	178.37	/		
27	8.764	220	7.5	13.9	0.06	0	/		
28	8.2512	157	7.5	13.4	0.22	175.82	/		
29	7.6632	234	7.5	14.1	0.48	0	/		
30	7.4616	210	7.5	12.4	0.39	177.71	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	248.008	189	9.02	14.1	0.235	2551.99	/	710101	



# 污水处理厂运行情况记录表

2021年7月(一期)

企业单位名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)
		进水	出水	进水	出水			
1	9.9606	197	15	13.9	0.16	150.16	/	828590
2	9.7	148	7.5	14	0.38	0	/	
3	9.7232	178	7.5	14.4	0.72	150.3	/	
4	9.5288	211	7.5	15	0.25	0	/	
5	9.9288	184	7.5	15	0.08	149.61	/	
6	9.944	89	16	14.4	0.09	0	/	
7	9.6144	128	7.5	10.5	0.1	0	/	
8	10.0472	131	7.5	15.2	0.06	0	/	
9	6.9048	134	7.5	16.4	0.1	93.45	/	
10	10.3976	154	7.5	17.1	0.04	0	/	
11	9.9976	148	7.5	15.2	0.05	149.12	/	
12	10.2144	142	7.5	13.1	0.17	0	/	
13	9.7336	158	7.5	13.9	0.06	149.61	/	
14	10.5587	112	7.5	13.5	0.16	0	/	
15	10.557	128	7.5	12.2	0.25	148.99	/	
16	10.9196	127	7.5	12.6	0.07	0	/	
17	8.7538	203	7.5	10.7	0.08	147.47	/	
18	10.6952	149	19	13.6	0.07	0	/	
19	11.0312	152	7.5	10.9	0.1	148.99	/	
20	11.1323	105	7.5	4.97	0.06	0	/	
21	11.0056	67	7.5	5.16	0.06	134.76	/	
22	11.1418	68	7.5	7.69	0.07	0	/	
23	11.1731	129	7.5	11.6	0.15	118.04	/	
24	11.0914	100	7.5	11.6	0.3	0	/	
25	11.0605	101	7.5	11.9	0.09	117.14	/	
26	11.6162	91	7.5	12.6	0.33	0	/	
27	11.7437	152	7.5	13.2	0.06	114.38	/	
28	10.7106	124	7.5	13.3	0.35	0	/	
29	9.987	118	7.5	17.2	0.31	111	/	
30	8.1999	123	7.5	17	0.23	0	/	
31	8.7962	133	7.5	18.2	0.59	88.76	/	
合计 (或加权 平均)	315.8688	134	8.39	12.9	0.177	1971.78	/	828590

# 污水处理厂运行情况记录表

2021年7月（二期）

企业名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)
		进水	出水	进水	出水			
1	9.1128	201	7.5	13.2	0.14	0	/	760320
2	8.8272	150	7.5	12.3	0.37	143.45	/	
3	8.8648	178	7.5	13	0.73	0	/	
4	8.968	160	7.5	14.1	0.26	150.16	/	
5	9.1912	165	7.5	12.5	0.09	0	/	
6	9.276	114	7.5	12.6	0.09	150.23	/	
7	9.2	182	7.5	10.8	0.11	149.82	/	
8	9.6568	112	7.5	12.3	0.02	150.16	/	
9	6.6184	102	7.5	13.2	0.07	18.65	/	
10	9.9032	174	7.5	12.7	0.03	148.99	/	
11	9.384	198	7.5	12.4	0.05	0	/	
12	9.6656	132	7.5	9.85	0.2	149.4	/	
13	9.0024	297	7.5	12.8	0.06	0	/	
14	9.8304	142	7.5	13.6	0.15	149.4	/	
15	9.4768	235	17	12.9	0.28	0	/	
16	9.2248	180	7.5	13.3	0.07	148.16	/	
17	7.2928	671	18	11.5	0.07	0	/	
18	9.3552	201	7.5	14.8	0.07	148.23	/	
19	10.0544	168	7.5	10.7	0.04	0	/	
20	10.0544	129	7.5	4.97	0.06	133.86	/	
21	10.085	101	7.5	5.2	0.06	0	/	
22	10.256	119	7.5	8.78	0.07	116.18	/	
23	10.32	190	7.5	11.8	0.12	0	/	
24	10.2128	117	7.5	13.7	0.27	116.59	/	
25	10.2024	148	7.5	15.2	0.08	0	/	
26	10.7864	135	7.5	17.8	0.32	111.41	/	
27	10.9848	172	7.5	16	0.07	0	/	
28	10.0632	117	7.5	13.3	0.35	113.83	/	
29	9.0488	114	7.5	17.1	0.32	0	/	
30	7.1528	154	7.5	20.2	0.28	106.16	/	
31	7.7719	134	7.5	19.6	0.59	0	/	
合计 (或加权 平均)	289.8433	170	8.07	12.9	0.173	2204.68	/	760320



# 污水处理厂运行情况记录表

2021年8月(一期)

企业单位名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万)	COD(毫克/升)		氨氮(毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.6634	157	7.5	15.5	0.2	77.25	/	839653	注: cod、氨氮 进出水 浓度均 为企业 自测数 据
2	9.1294	184	7.5	15.2	0.1	0	/		
3	9.6777	155	7.5	13.7	0.16	88.72	/		
4	10.8742	125	7.5	8.95	0.08	0	/		
5	11.6835	85	7.5	8.64	0.08	100.25	/		
6	10.6379	143	7.5	13.4	0.47	0	/		
7	11.2471	89	15	12.3	0.11	103.89	/		
8	9.015	153	7.5	14.1	0.05	0	/		
9	11.53	133	7.5	11	0.19	105.53	/		
10	11.2195	150	7.5	5.56	0.05	0	/		
11	11.5584	98	7.5	8.26	0.14	102.32	/		
12	11.6121	78	7.5	10.7	0.37	0	/		
13	11.7702	91	7.5	10.6	0.28	101.59	/		
14	11.7712	147	7.5	10.4	0.23	0	/		
15	11.4135	86	18	12	0.23	102.56	/		
16	8.6084	115	7.5	13.2	0.11	0	/		
17	10.9213	112	7.5	12.9	0.91	0	/		
18	10.7491	138	17	12.6	0.17	0	/		
19	8.9524	116	7.5	13.6	0.1	71.12	/		
20	10.7515	104	7.5	13	0.12	0	/		
21	11.1752	119	7.5	13.1	0.15	71.91	/		
22	11.7825	113	7.5	13.6	0.23	0	/		
23	11.5383	108	7.5	13.1	0.51	71.85	/		
24	10.8387	127	7.5	10.9	0.18	72.34	/		
25	11.7421	116	7.5	8.17	0.46	71.37	/		
26	11.4282	81	19	10.6	0.28	0	/		
27	10.4122	135	16	13.2	0.6	64.99	/		
28	10.5757	97	7.5	13.3	0.6	0	/		
29	9.5845	92	7.5	15.6	1.05	66.09	/		
30	9.1239	112	7.5	15.2	0.33	0	/		
31	9.0842	154	7.5	16.9	0.52	73.07	/		
合计 (或加权 平均)	329.071	118	9.1	12.1	0.292	1344.85	/	839653	



## 污水处理厂运行情况记录表

### 2021年8月（二期）

企业单位名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	7.3808	229	7.5	15	0.14	0	/	772357	注：cod、氨氮进出水浓度均为企业自测数据
2	7.7786	201	7.5	15.6	0.09	91.02	/		
3	8.6808	210	7.5	16.9	0.15	0	/		
4	9.6467	189	7.5	11.5	0.08	94.18	/		
5	10.9059	112	7.5	9.48	0.07	0	/		
6	10.0347	153	7.5	14.8	0.55	100.01	/		
7	10.3274	124	7.5	13	0.15	0	/		
8	8.174	119	7.5	11.8	0.06	98.74	/		
9	10.8766	150	7.5	13.3	0.14	0	/		
10	10.5625	119	7.5	6.36	0.06	101.47	/		
11	10.8259	115	7.5	9.31	0.12	0	/		
12	10.8766	115	7.5	11	0.36	103.41	/		
13	11.0465	108	7.5	12.6	0.24	0	/		
14	11.0399	169	7.5	11.3	0.23	101.1	/		
15	10.6322	132	7.5	11.9	0.22	0	/		
16	7.6242	128	7.5	13.6	0.12	73.19	/		
17	10.0162	138	7.5	13.2	0.98	70.64	/		
18	9.7496	171	7.5	13	0.17	71.18	/		
19	7.9758	137	7.5	13.7	0.11	0	/		
20	10.0931	123	15	12.6	0.12	70.09	/		
21	10.3985	147	7.5	12.8	0.13	0	/		
22	11.1176	114	7.5	13.2	0.22	71.43	/		
23	10.9084	118	7.5	12.3	0.52	0	/		
24	10.0228	129	7.5	12.8	0.19	0	/		
25	11.3216	122	7.5	9.85	0.44	0	/		
26	10.7039	194	20	12.8	0.25	73.98	/		
27	9.4964	159	7.5	13.5	0.59	0	/		
28	9.7033	155	7.5	13.5	0.64	66.88	/		
29	8.4223	125	7.5	16.5	0.55	0	/		
30	8.0061	137	18	16.1	0.28	64.39	/		
31	8.3481	147	7.5	16.5	0.45	0	/		
合计 (或加权平均)	302.697	143	8.47	12.7	0.274	1251.71	/	772357	



# 污水处理厂运行情况记录表

2021年9月(一期)

企业单位名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水			
1	9.8006	133	7.5	16.4	0.04	88.49	/	838083 注: cod、 氨氮进出 水浓度均 为企业自 测数据
2	9.8025	125	7.5	14.1	0.8	0	/	
3	11.1353	145	7.5	15.5	2.78	0	/	
4	11.2772	131	7.5	14.5	0.11	0	/	
5	10.9327	156	17	13.8	0.06	95.51	/	
6	11.4618	81	17	14.7	0.06	101.5	/	
7	11.7207	94	7.5	15.3	0.18	108.41	/	
8	12.4209	130	7.5	19.1	0.43	106.65	/	
9	12.0231	128	7.5	16.3	0.09	66.2	/	
10	12.2596	116	15	12	0.01	108.24	/	
11	11.9711	125	7.5	15.2	0.05	108.07	/	
12	11.7761	143	7.5	14.7	0.08	0	/	
13	11.8895	137	7.5	16.1	0.18	68.97	/	
14	11.7822	124	7.5	15.6	0.03	0	/	
15	11.7455	128	7.5	16.6	0.03	100.26	/	
16	11.9867	124	7.5	10.8	0.1	0	/	
17	12.7291	104	7.5	8.88	0.05	82.21	/	
18	12.5463	105	7.5	10.5	0.08	0	/	
19	8.329	130	7.5	11.9	0.21	59.18	/	
20	12.2191	141	7.5	14.5	0.27	0	/	
21	12.0344	172	7.5	18.3	0.4	115.87	/	
22	11.4715	128	7.5	15.6	0.06	0	/	
23	12.1741	122	7.5	12.2	0.07	114.23	/	
24	12.5478	130	7.5	7.8	0.03	0	/	
25	12.2453	721	7.5	13.5	0.05	115.31	/	
26	11.5777	143	7.5	14.3	0.1	0	/	
27	10.5943	99	7.5	15	0.09	95.05	/	
28	10.8472	130	7.5	15.4	0.03	0	/	
29	10.5991	92	7.5	15.4	0.08	0	/	
30	10.9074	124	7.5	16.5	0.11	0	/	
/	/	/	/	/	/	/	/	
合计 (或加权 平均)	344.808	147	8.38	14.3	0.216	1534.15	/	838083

## 污水处理厂运行情况记录表

### 2021年9月（二期）

企业单位名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.6971	121	25	16.6	0.05	0	/	807487	注：cod、氨氮进出水浓度均为企业自测数据
2	8.605	133	7.5	15.3	0.81	81.81	/		
3	10.2177	182	7.5	12.5	1.81	94.83	/		
4	10.4326	130	7.5	16.4	0.12	95	/		
5	10.4543	128	7.5	11.6	0.06	0	/		
6	10.827	162	7.5	13.4	0.06	0	/		
7	10.9598	136	7.5	15.3	0.2	0	/		
8	11.6247	120	7.5	13.8	0.42	0	/		
9	11.1754	134	7.5	14.8	0.07	36.66	/		
10	11.337	138	7.5	14.3	0.01	0	/		
11	10.9857	145	7.5	16.4	0.05	0	/		
12	10.7347	167	7.5	15.2	0.07	73.67	/		
13	10.9389	160	7.5	16.6	0.14	0	/		
14	10.8492	160	7.5	14.7	0.03	80	/		
15	10.8208	161	7.5	16.1	0.04	0	/		
16	11.5101	164	7.5	13.6	0.09	114.74	/		
17	12.7436	121	7.5	11.2	0.05	0	/		
18	12.5532	132	7.5	12	0.07	116.72	/		
19	8.3461	166	7.5	13.9	0.19	38.93	/		
20	12.2297	166	7.5	14.6	0.28	116.27	/		
21	12.0899	133	7.5	15.3	0.4	0	/		
22	11.4583	118	7.5	14.9	0.03	115.03	/		
23	12.3205	153	7.5	13.6	0.07	0	/		
24	12.7558	154	7.5	9.81	0.03	113.72	/		
25	12.4673	167	7.5	14.6	0.04	0	/		
26	11.753	253	7.5	15.5	0.09	75.87	/		
27	10.6787	120	7.5	15	0.07	0	/		
28	10.959	128	7.5	15.6	0.03	105.18	/		
29	10.6913	119	7.5	17.6	0.04	111.57	/		
30	11.0035	155	7.5	17.1	0.07	112.76	/		
/	/	/	/	/	/	/	/		
合计 (或加权平均)	332.22	148	7.96	14.5	0.174	1482.76	/	807487	



# 污水处理厂运行情况记录表

2021年10月(一期)

企业单位名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	11.7225	183	7.5	15.9	0.08	115.48	/	816189	注: cod、氨氮进出水浓度均为企业自测数据; 10月19日18:50至10月20日0:30, 因供电公司变电所故障, 导致全厂突发停电, 停产
2	11.0162	171	7.5	16.6	0.01	0	/		
3	11.6638	177	7.5	15.1	0.03	119.43	/		
4	10.6201	138	7.5	12.2	0.01	0	/		
5	10.3735	117	7.5	11.9	0.07	119.73	/		
6	11.4602	102	7.5	12	0.01	0	/		
7	12.3631	127	7.5	12.2	0.03	120.71	/		
8	12.224	176	7.5	4.88	0.03	0	/		
9	12.0001	95	7.5	3.16	0.18	114.26	/		
10	11.8502	155	7.5	3.87	0.08	0	/		
11	12.0218	72	7.5	6.46	0.02	43.74	/		
12	12.2333	75	7.5	10	0.03	0	/		
13	12.539	117	7.5	4.77	0.02	0	/		
14	12.207	79	7.5	6.2	0.01	0	/		
15	11.4411	101	7.5	7.19	0.04	14.36	/		
16	12.2807	67	7.5	8.46	0.04	0	/		
17	12.7544	72	7.5	11.6	0.05	72.4	/		
18	12.6493	98	7.5	12.8	0.24	0	/		
19	11.3376	133	7.5	13	0.39	55.12	/		
20	9.576	95	7.5	15.1	0.09	0	/		
21	12.2936	103	7.5	16.4	0.04	71.97	/		
22	12.4209	119	7.5	15.3	0.07	0	/		
23	12.5745	94	7.5	16.7	0.08	79.82	/		
24	12.4039	81	7.5	16.7	0.01	0	/		
25	12.2097	103	7.5	17.2	0.01	75.56	/		
26	12.069	104	7.5	16.5	0.06	0	/		
27	12.2941	107	7.5	19.4	0.1	78.97	/		
28	12.3164	112	7.5	17.9	0.02	0	/		
29	12.227	167	7.5	17.4	0.04	76.17	/		
30	12.3329	129	7.5	19	0.06	0	/		
31	11.9475	103	7.5	19.7	0.14	76.54	/		
合计 (或加权平均)	369.423	115	7.5	12.8	0.067	1234.26	/	816189	

# 污水处理厂运行情况记录表

2021年10月（二期）

企业单位名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	11.8557	192	7.5	15	0.09	0	/	825431	注：cod、氨氮进出水浓度均为企业自测数据；10月19日18:50至10月20日0:30，因供电公司变电所故障，导致全厂突发停电，停产
2	11.1112	224	7.5	16.5	0.02	120.59	/		
3	11.8011	210	7.5	13.8	0.03	0	/		
4	10.6771	129	7.5	13.2	0.03	120.16	/		
5	10.4317	125	7.5	12.4	0.07	0	/		
6	11.5946	112	7.5	12.1	0.01	120.04	/		
7	12.5602	121	7.5	12.5	0.03	0	/		
8	12.3694	301	7.5	4.35	0.05	118.27	/		
9	12.1056	109	7.5	2.78	0.05	0	/		
10	11.9452	62	7.5	3.25	0.06	115.05	/		
11	12.1079	82	7.5	6.8	0.01	0	/		
12	12.3785	99	7.5	9.66	0.02	13.32	/		
13	12.6755	112	7.5	5.08	0.01	18.56	/		
14	12.339	80	7.5	6.56	0.01	0	/		
15	11.5097	152	7.5	6.29	0.02	0	/		
16	12.4081	146	7.5	10.6	0.05	74.41	/		
17	12.9094	106	7.5	10.1	0.05	0	/		
18	12.8481	110	7.5	11.3	0.23	73.74	/		
19	10.7441	144	7.5	12.3	0.42	0	/		
20	10.4608	109	7.5	12.7	0.09	55.55	/		
21	12.3957	129	7.5	13.5	0.03	0	/		
22	12.5421	155	7.5	12.8	0.07	71.43	/		
23	12.7588	89	7.5	12.6	0.04	0	/		
24	12.5795	101	7.5	13.4	0.01	74.04	/		
25	12.3693	99	7.5	13.3	0.04	0	/		
26	12.2402	96	7.5	12.2	0.17	76.11	/		
27	12.4879	100	7.5	14.6	0.13	0	/		
28	12.4886	108	7.5	15.7	0.05	78.67	/		
29	12.3702	193	7.5	15.4	0.03	0	/		
30	12.4888	169	7.5	17.9	0.04	78.06	/		
31	12.0524	126	7.5	17.8	0.14	0	/		
合计 (或加权平均)	373.606	132	7.5	11.5	0.067	1208	/	825431	



# 污水处理厂运行情况记录表

2021年11月(一期)

企业单位名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	12.2687	95	7.5	18.4	0.07	77.38	/	818162	注: cod、氨氮进出水浓度均为企业自测数据
2	12.4664	111	7.5	15.9	0.1	0	/		
3	12.0647	126	7.5	18.7	0.2	75.77	/		
4	12.2472	110	7.5	18.4	0.08	0	/		
5	12.1644	114	7.5	15.7	0.04	73.35	/		
6	12.1369	140	7.5	18.1	0.03	0	/		
7	11.5364	119	7.5	16.8	0.04	78.56	/		
8	11.5223	124	7.5	15.8	0.03	0	/		
9	12.3133	76	7.5	15.7	0.07	76.33	/		
10	12.3409	124	7.5	17.8	0.03	0	/		
11	12.2553	95	7.5	17.7	0.08	75.71	/		
12	12.0886	181	7.5	16.8	0.02	0	/		
13	11.8608	161	7.5	18	0.07	74.09	/		
14	10.9728	169	7.5	17.9	0.04	0	/		
15	10.844	113	7.5	17.9	0.08	72.42	/		
16	11.1937	115	7.5	16.7	0.08	0	/		
17	11.7517	124	7.5	18.6	0.09	100.71	/		
18	10.1511	168	7.5	15.5	0.52	0	/		
19	11.1988	158	7.5	17.9	0.27	102.39	/		
20	12.089	92	7.5	18.3	0.05	0	/		
21	11.4143	133	7.5	17.4	0.09	54.55	/		
22	10.9742	103	7.5	17.9	0.08	0	/		
23	11.2598	92	7.5	18.3	0.14	103.51	/		
24	11.5654	94	7.5	16.7	0.06	0	/		
25	11.1818	120	7.5	18.9	0.04	101.4	/		
26	10.7871	198	7.5	17.1	0.23	0	/		
27	11.9158	117	7.5	13	0.05	101.4	/		
28	7.3122	130	7.5	22.5	0.05	0	/		
29	10.2491	103	7.5	17.1	0.17	99.29	/		
30	11.1823	105	7.5	20.9	0.15	0	/		
/	/	/	/	/	/	/	/		
合计 (或加权平均)	343.309	123	7.5	17.5	0.099	1266.86	/	818162	

## 污水处理厂运行情况记录表

### 2021年11月（二期）

企业单位名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	12.4029	107	7.5	15.6	0.01	0	/	829798	注：cod、氨氮进出水浓度均为企业自测数据
2	12.6234	170	7.5	13.5	0.06	77.86	/		
3	12.2019	139	7.5	15.4	0.13	0	/		
4	12.3562	133	7.5	14.9	0.09	75.89	/		
5	12.2789	130	7.5	13.5	0.04	0	/		
6	12.2491	172	7.5	15.3	0.02	79.06	/		
7	11.6049	151	7.5	16.6	0.03	0	/		
8	11.5733	142	7.5	13.9	0.03	78.75	/		
9	12.4032	95	7.5	13.2	0.08	0	/		
10	12.4286	140	7.5	14.7	0.02	77.51	/		
11	12.3557	108	7.5	14.6	0.05	0	/		
12	12.1805	130	7.5	15.8	0.01	75.58	/		
13	11.9197	164	7.5	16.2	0.03	0	/		
14	10.9802	131	7.5	16.8	0.06	74.03	/		
15	10.8438	132	7.5	15.7	0.07	0	/		
16	11.2193	137	7.5	16	0.06	85.57	/		
17	11.8137	141	7.5	15.5	0.13	0	/		
18	10.1123	110	7.5	17.2	0.07	96.06	/		
19	11.203	158	7.5	14.8	0.02	0	/		
20	12.0867	91	7.5	15.1	0.04	63.23	/		
21	11.5291	140	7.5	15.7	0.09	0	/		
22	11.0643	140	7.5	18	0.06	93.21	/		
23	11.3337	130	7.5	15	1.12	0	/		
24	11.6471	131	7.5	15	0.1	104.06	/		
25	11.2658	122	7.5	16	0.04	0	/		
26	10.8479	232	7.5	15.7	0.05	101.95	/		
27	12.0252	183	7.5	15.4	0.05	0	/		
28	10.1846	235	7.5	21.4	0.03	100.34	/		
29	10.2808	149	7.5	18.9	0.1	0	/		
30	11.1755	134	7.5	19	0.14	100.59	/		
/	/	/	/	/	/	/	/		
合计 (或加权平均)	348.1913	142	7.5	15.7	0.093	1283.69	/	829798	



# 污水处理厂运行情况记录表

2021年12月(一期)

企业单位名称(盖章): 中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	9.7615	192	7.5	16.8	0.12	97.68	/	815674	注: cod、氨氮 进出水 浓度均 为企业 自测数 据
2	10.2169	203	7.5	14.2	0.01	0	/		
3	9.0692	170	7.5	17.9	0.04	99.71	/		
4	9.1918	126	7.5	21.1	0.2	0	/		
5	11.0183	117	7.5	16.8	0.07	103.29	/		
6	10.7679	108	7.5	16.6	0.01	0	/		
7	10.9266	103	7.5	16.3	0.08	95.46	/		
8	10.8117	122	7.5	15.5	0.08	0	/		
9	10.3624	108	7.5	16.8	0.07	95.21	/		
10	9.7373	694	7.5	21.5	0.02	0	/		
11	9.4926	444	21	21.2	0.25	95.46	/		
12	9.6812	253	7.5	25.6	0.43	0	/		
13	10.474	233	7.5	21.7	0.35	98.85	/		
14	9.2372	143	7.5	21.8	0.06	0	/		
15	9.9394	209	7.5	24.3	0.09	104.21	/		
16	9.0354	113	7.5	23.5	0.1	0	/		
17	8.9304	120	7.5	22.5	0.04	102.36	/		
18	10.0932	189	7.5	22.2	0.02	0	/		
19	10.2054	135	7.5	20.6	0.02	100.82	/		
20	10.4192	140	7.5	17.7	0.13	0	/		
21	11.5174	93	7.5	9.53	0.1	98.48	/		
22	11.5691	100	7.5	16.2	0.21	0	/		
23	11.455	122	7.5	17.2	0.06	107.85	/		
24	11.325	139	7.5	19.2	0.21	0	/		
25	11.6096	246	7.5	19.6	0.08	105.81	/		
26	11.781	148	7.5	21.7	0.03	0	/		
27	11.5498	94	7.5	19.8	0.03	104.33	/		
28	11.3818	206	7.5	20.4	0.38	0	/		
29	10.314	129	7.5	23.2	0.1	86.22	/		
30	9.8206	120	7.5	23.4	0.7	0	/		
31	10.4296	176	7.5	19.6	0.52	0	/		
合计 (或加权 平均)	322.1245	175	7.9	19.4	0.148	1495.74	/	815674	

# 污水处理厂运行情况记录表

2021年12月（二期）

企业单位名称（盖章）：中山市污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	9.8004	126	7.5	16.4	0.1	0	/	821726	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	10.1831	174	7.5	13.1	0.01	102.61	/		
3	9.1451	191	7.5	17.8	0.04	0	/		
4	9.2499	142	7.5	19.6	0.17	99.65	/		
5	11.221	132	7.5	17	0.04	0	/		
6	10.9838	135	7.5	18.5	0.11	96.75	/		
7	11.1368	106	7.5	14.8	0.03	0	/		
8	11.0228	125	7.5	13.9	0.06	96.51	/		
9	10.5474	116	7.5	15.2	0.03	0	/		
10	9.8758	197	7.5	18.6	0.09	83.93	/		
11	9.599	179	7.5	18	0.02	0	/		
12	9.7772	136	7.5	21.5	0.39	97.86	/		
13	10.6281	148	7.5	19.6	0.28	0	/		
14	9.3048	133	7.5	19.7	0.09	102.61	/		
15	10.0198	135	7.5	21.1	0.06	0	/		
16	9.0226	126	7.5	21.2	0.08	104.27	/		
17	8.9368	171	16	21.9	0.04	0	/		
18	10.1224	223	7.5	20	0.02	102.85	/		
19	10.2471	153	7.5	19.5	0.03	0	/		
20	10.458	191	7.5	17.4	0.13	101.19	/		
21	11.6187	115	7.5	11.1	0.06	0	/		
22	11.6671	96	7.5	14.8	0.21	106.98	/		
23	11.5515	122	7.5	16.6	0.06	0	/		
24	11.404	128	7.5	17.4	0.18	108.71	/		
25	11.6954	269	7.5	17.6	0.13	0	/		
26	11.8808	136	7.5	18.7	0.04	107.11	/		
27	11.5906	117	7.5	18.2	0.02	0	/		
28	11.3744	155	7.5	20.2	0.37	104.76	/		
29	10.2834	226	7.5	21.5	0.03	0	/		
30	9.7502	164	7.5	20.4	0.68	102.24	/		
31	10.4165	212	7.5	18.7	0.42	100.14	/		
合计 (或加权 平均)	324.5145	153	7.73	18	0.129	1618.17	/	821726	