

中山市珍家山污水处理有限公司运行情况记录表

2022年1月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	12.2426	114	7.5	17.9	0.19	75.09	/	671520	注：cod、氨氮进出水浓度均为企业自测数据
2	12.5992	116	7.5	19.6	0.19	38.94	/		
3	12.5275	110	7.5	18.7	0.19	14.66	/		
4	12.3465	110	7.5	17.6	0.22	24.84	/		
5	12.2582	135	7.5	17.1	0.04	78.96	/		
6	12.3377	109	7.5	16.8	0.01	76.98	/		
7	12.0651	93	7.5	19	0.01	37.78	/		
8	12.294	131	7.5	17.7	0.01	21.36	/		
9	12.3952	117	7.5	17.1	0.1	19.59	/		
10	12.1022	133	7.5	18.8	0.03	31.21	/		
11	12.6744	148	7.5	20.1	0.54	30.9	/		
12	12.1192	109	7.5	22.1	0.15	67.59	/		
13	11.8246	125	7.5	18.9	0.09	81.95	/		
14	12.7076	105	7.5	16.8	0.49	45.78	/		
15	12.4007	92	7.5	17.8	0.2	61.29	/		
16	12.15	130	7.5	22	0.27	91.85	/		
17	11.9148	96	7.5	20	0.11	32.66	/		
18	12.4389	112	7.5	18.9	0.33	48.95	/		
19	12.9453	114	7.5	18	0.05	64.09	/		
20	12.917	107	7.5	17	0.07	37	/		
21	13.5319	82	7.5	18	0.2	50.72	/		
22	13.9838	90	7.5	14.8	0.18	38.03	/		
23	13.7641	133	7.5	19	0.68	38.66	/		
24	13.5241	114	7.5	16.3	0.36	71.01	/		
25	13.2641	118	7.5	16.5	0.3	66.53	/		
26	13.6058	118	18	18.4	0.6	62.29	/		
27	13.2437	138	7.5	15.8	0.52	72.6	/		
28	12.8047	96	7.5	14.1	0.3	109.95	/		
29	12.6476	96	7.5	14.2	0.13	80.04	/		
30	12.7469	72	7.5	18.9	0.01	65.59	/		
31	12.9027	79	7.5	14.6	0.01	92.59	/		
合计 (或加权平均)	393.2801	111	7.86	17.8	0.217	1729.48	/	671520	

中山市珍家山污水处理有限公司运行情况记录表

2022年2月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	13.0618	200	7.5	10.8	0.05	76.78	/	557364	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	12.7596	70	7.5	7.53	0.02	66.22	/		
3	12.1065	79	7.5	9.81	0.02	54.53	/		
4	12.0479	54	7.5	10.1	0.04	41.29	/		
5	12.3774	67	7.5	11	0.04	48.45	/		
6	12.454	58	7.5	11	0.09	65.93	/		
7	12.2312	60	7.5	12.4	0.05	45.32	/		
8	11.628	83	7.5	14.4	0.35	26.39	/		
9	12.05	94	7.5	16.5	0.5	38.42	/		
10	12.1828	100	7.5	16.8	1.26	28.51	/		
11	13.2859	117	7.5	16.5	1.12	11.68	/		
12	12.6035	117	7.5	19.8	1.55	32.45	/		
13	12.4192	114	7.5	17.2	0.38	0	/		
14	12.3836	102	7.5	15.6	0.2	0	/		
15	13.3525	90	7.5	14.4	0.35	0	/		
16	13.2186	96	7.5	14.3	0.08	0	/		
17	12.3944	93	7.5	13.8	0.07	0	/		
18	11.9526	99	7.5	18	0.03	0	/		
19	12.3281	149	7.5	11	0.17	12.23	/		
20	12.7225	54	7.5	3.66	0.02	24.58	/		
21	12.8133	38	7.5	2.92	0.02	34.22	/		
22	12.8854	54	7.5	4.79	0.04	14.84	/		
23	12.7342	50	7.5	6.05	0.06	25.92	/		
24	12.5822	108	7.5	8.07	0.04	39.19	/		
25	12.7927	88	7.5	10.8	0.05	35.19	/		
26	12.6674	102	7.5	11.2	0.06	24.96	/		
27	12.6219	86	7.5	11.6	0.08	31.72	/		
28	12.5566	104	7.5	11.8	0.11	39.58	/		
/	/	/	/	/	/	/	/		
/	/	/	/	/	/	/	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	351.214	90.4	7.5	11.8	0.245	818.4	/	557364	

中山市珍家山污水处理有限公司运行情况记录表

2022年3月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	11.9629	124	7.5	14.8	0.26	48.32	/	677585	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	11.4446	98	7.5	12.8	0.07	32.25	/		
3	12.5716	107	7.5	14.2	0.08	0	/		
4	12.7886	124	7.5	15.7	0.25	34.19	/		
5	11.7219	96	7.5	17	0.06	68.2	/		
6	11.1772	93	7.5	14.2	0.02	82.64	/		
7	11.4819	139	7.5	17	0.14	53.34	/		
8	12.069	135	7.5	15.6	0.17	35.46	/		
9	12.4043	146	7.5	17.7	0.15	43.44	/		
10	11.908	130	7.5	16.9	0.14	47.77	/		
11	11.8437	127	7.5	20	0.37	59.09	/		
12	11.0214	273	7.5	23.1	0.2	70.44	/		
13	10.5105	95	7.5	19.2	0.01	54.06	/		
14	11.3777	167	7.5	21.9	0.01	18.44	/		
15	11.5284	132	7.5	18.7	0.01	56.61	/		
16	11.5117	131	7.5	17.5	0.01	32.01	/		
17	11.5694	111	7.5	19.2	0.01	54.82	/		
18	11.6309	118	7.5	20.4	0.07	40.97	/		
19	11.4662	105	7.5	18.7	0.04	0	/		
20	11.366	148	7.5	16.4	0.01	0	/		
21	11.2591	74	7.5	15.3	0.01	0	/		
22	11.9381	140	7.5	15.8	0.09	0	/		
23	11.7035	170	7.5	10.2	0.01	16.52	/		
24	12.2428	132	7.5	11.6	0.01	74.07	/		
25	12.9389	134	7.5	12.3	0.01	105.45	/		
26	13.2555	141	7.5	17.2	0.36	45.29	/		
27	13.4046	134	7.5	13.2	0.02	30.46	/		
28	13.4689	110	7.5	11	0.06	40.78	/		
29	12.603	99	7.5	13.3	0.25	48.33	/		
30	13.4057	113	7.5	14.9	0.1	40.8	/		
31	12.8801	81	7.5	16.2	0.01	26.94	/		
合计 (或加权 平均)	372.456	126	7.5	16.1	0.099	1260.69	/	677585	

中山市珍家山污水处理有限公司运行情况记录表

2022年4月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	13.1612	80	7.5	13.5	0.07	(吨)	/	659098	注：cod、氨氮进出水浓度均为企业自测数据，2022年4月18日9:00-19日18:00，19日23:00-20日9:00因二期扩建工程需新旧消毒渠道管道接驳，及在线仪表房迁改。停产43小时。
2	14.0568	82	7.5	13.6	0.13	94.35	/		
3	13.744	118	7.5	13	0.2	109.76	/		
4	13.8356	97	7.5	14.5	0.16	87.05	/		
5	13.7602	142	7.5	20	0.01	115.14	/		
6	12.7634	134	7.5	19.6	0.14	73.93	/		
7	12.2388	146	7.5	20.9	0.15	64.62	/		
8	12.2364	161	7.5	21.1	0.35	51.51	/		
9	13.3854	167	7.5	20.3	0.25	65.83	/		
10	12.1036	160	7.5	23.6	0.04	58.11	/		
11	11.657	161	7.5	24	0.01	55.74	/		
12	11.5104	148	7.5	25.6	0.04	20.32	/		
13	11.7959	132	7.5	22.9	0.08	72.79	/		
14	11.9559	181	7.5	21.9	0.04	58.05	/		
15	14.1154	167	7.5	14.6	0.04	66.72	/		
16	13.7234	92	7.5	14.5	0.04	67.26	/		
17	13.3551	103	7.5	16.6	0.39	53.08	/		
18	4.9272	/	/	/	/	59.21	/		
19	0.9304	/	/	/	/	49.96	/		
20	6.5897	84	7.5	20.8	0.02	0	/		
21	11.398	154	7.5	19.4	0.36	39.46	/		
22	10.7632	106	18	16.4	0.1	10.71	/		
23	10.7144	103	7.5	18.8	0.08	64.86	/		
24	10.1753	69	7.5	18.4	0.05	42.74	/		
25	11.0806	122	7.5	19.9	0.06	67.68	/		
26	12.1188	139	7.5	21.5	0.07	59.12	/		
27	12.2755	128	7.5	21	0.05	89.2	/		
28	12.0828	134	7.5	20.2	0.06	33.71	/		
29	11.8901	115	7.5	17.4	0.05	43.57	/		
30	11.7797	114	7.5	15.3	0.13	47.89	/		
/	/	/	/	/	/	/	/		
合计 (或加权平均)	346.124	127	7.83	18.7	0.116	1722.37	/	659098	

中山市珍家山污水处理有限公司运行情况记录表

2022年5月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	12.4043	75	7.5	5.33	0.12	65.83	/	691046	注： 2022年5月5日 20:30-23:00因 停电， 停产2.5 小时。 cod、氨 氮进出 水浓度 均为企 业自测 数据
2	12.08	64	7.5	3.53	0.46	78.03	/		
3	11.4384	83	7.5	8.9	0.12	78.91	/		
4	12.0681	52	7.5	10.6	0.01	74.25	/		
5	10.6142	130	7.5	13.9	0.03	36.99	/		
6	10.2731	119	7.5	17.7	0.12	40.07	/		
7	11.6483	96	7.5	18.6	0.03	46.38	/		
8	10.6142	137	7.5	20.6	0.27	0	/		
9	12.2331	101	7.5	19.8	0.24	0	/		
10	12.1477	136	7.5	18.3	0.03	0	/		
11	12.2311	91	7.5	11.3	0.05	23	/		
12	12.0377	118	7.5	3.7	0.01	21.01	/		
13	12.1401	70	7.5	2.63	0.01	45.46	/		
14	12.2352	50	7.5	3.71	0.01	53.04	/		
15	12.131	46	7.5	4.31	0.04	82.31	/		
16	12.2191	44	7.5	5.97	0.02	99.67	/		
17	12.2066	70	7.5	8.55	0.02	85.64	/		
18	12.1371	46	7.5	9.97	0.01	48.84	/		
19	12.2421	93	7.5	11.8	0.01	85.49	/		
20	12.0574	126	7.5	14.7	0.29	102.31	/		
21	12.1322	115	7.5	10.3	0.16	83.45	/		
22	12.1436	65	7.5	11.2	0.03	31.36	/		
23	12.1206	72	7.5	15	0.02	102.2	/		
24	12.0887	96	7.5	16.2	0.02	118.36	/		
25	12.1339	85	7.5	13.8	0.02	64.57	/		
26	12.2041	90	7.5	14.7	0.01	71.92	/		
27	12.1766	81	7.5	12.2	0.01	41.53	/		
28	12.2317	70	7.5	11.1	0.01	80.94	/		
29	12.1148	74	7.5	12.1	0.02	78.66	/		
30	12.0876	100	7.5	11.5	0.01	68.71	/		
31	11.991	109	7.5	12.1	0.01	27.49	/		
合计 (或加权 平均)	370.584	86.6	7.5	11.3	0.071	1836.42	/	691046	

中山市珍家山污水处理有限公司运行情况记录表

2022年6月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含 水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	12.0573	80	7.5	11	0.01	62.27	/	663060	注：cod 、氨氮 进出水 浓度均 为企业 自测数 据
2	12.7864	66	7.5	10.8	0.01	60.6	/		
3	13.2397	61	7.5	6.05	0.01	58.21	/		
4	13.3626	56	7.5	8.28	0.01	29.52	/		
5	13.2033	96	7.5	12.4	0.06	17.62	/		
6	12.2054	85	7.5	11.2	0.02	23.86	/		
7	12.4742	68	7.5	6	0.12	30.65	/		
8	12.7813	71	7.5	4.05	0.01	12.27	/		
9	12.7601	57	7.5	5.34	0.01	46.53	/		
10	13.2842	53	7.5	5.34	0.01	43.84	/		
11	12.9632	32	7.5	3.48	0.03	36.7	/		
12	12.556	32	7.5	5.73	0.01	58.82	/		
13	12.4199	44	7.5	8.2	0.01	43.13	/		
14	12.0945	54	7.5	8.97	0.01	27.31	/		
15	12.3205	49	7.5	8.05	0.01	23.25	/		
16	12.0226	73	7.5	6.95	0.01	24.96	/		
17	12.0779	49	7.5	6.69	0.12	44.79	/		
18	13.3894	78	7.5	11.9	0.13	12.09	/		
19	13.447	68	7.5	11.5	0.08	23.36	/		
20	13.4844	63	7.5	10.4	0.17	46.71	/		
21	13.1246	61	7.5	11.7	0.01	27.97	/		
22	12.8707	63	7.5	13.1	0.01	45.3	/		
23	12.9073	51	7.5	12.6	0.01	23.5	/		
24	13.204	87	7.5	13.4	0.01	24.81	/		
25	12.9804	65	7.5	12.7	0.04	23.48	/		
26	13.1344	77	7.5	15	0.09	30.12	/		
27	13.1694	83	7.5	15.3	0.01	8.28	/		
28	12.2658	84	7.5	15.4	0.01	9.59	/		
29	11.0609	101	7.5	15.9	0.01	10.01	/		
30	11.1964	115	7.5	14.9	0.02	40.38	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	380.8438	67.1	7.5	10.1	0.036	969.93	/	663060	

中山市珍家山污水处理有限公司运行情况记录表

2022年7月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	12.8938	172	7.5	15.1	0.09	0	/	724460	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	13.3834	96	7.5	7.34	0.33	18.54	/		
3	13.3992	46	7.5	4.95	0.09	32.77	/		
4	13.1738	48	7.5	3.86	0.09	0	/		
5	13.3405	32	7.5	6.48	0.08	13.73	/		
6	13.1987	46	7.5	8.4	0.07	28.27	/		
7	13.1632	60	7.5	10.4	0.14	27.49	/		
8	13.2682	56	7.5	10.6	0.18	74.07	/		
9	13.1039	55	7.5	12.5	0.01	37.66	/		
10	13.0926	78	7.5	12.3	0.01	45.43	/		
11	13.3163	72	7.5	12.8	0.01	21.35	/		
12	13.4933	60	7.5	14	0.26	38.77	/		
13	13.4461	93	7.5	14.8	0.02	41.78	/		
14	13.5886	85	7.5	13.5	0.05	32.61	/		
15	13.5265	87	7.5	16	0.21	35.24	/		
16	13.2738	83	7.5	13.7	0.21	32.09	/		
17	12.9525	88	7.5	14.6	0.15	74.04	/		
18	11.0562	98	7.5	13.6	0.16	63.53	/		
19	13.222	84	7.5	14.9	0.15	48.03	/		
20	13.3886	90	7.5	14.5	0.16	0	/		
21	13.5494	75	7.5	15.2	0.17	16.69	/		
22	13.3013	103	7.5	18.3	0.15	20.12	/		
23	13.3414	104	7.5	16.9	0.22	40.11	/		
24	13.3922	77	7.5	16.1	0.05	45.36	/		
25	13.6762	105	7.5	17.1	0.06	32.17	/		
26	13.6189	85	7.5	15.1	0.05	83.5	/		
27	13.4702	77	7.5	13.1	0.07	44.51	/		
28	13.4387	93	7.5	17.4	0.01	51.22	/		
29	13.4709	70	7.5	14.6	0.06	30.93	/		
30	13.6017	86	7.5	13.9	0.11	41.79	/		
31	13.0353	98	7.5	13.1	0.05	44.49	/		
合计 (或加权 平均)	411.177	80.6	7.5	13.1	0.112	1116.29	/	724460	

中山市珍家山污水处理有限公司运行情况记录表

2022年8月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	12.953	100	7.5	15.35	0.13	34.97	/	694382	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	12.8727	109	7.5	17.25	0.005	71.36	/		
3	12.9788	118	7.5	14.74	0.38	45.78	/		
4	13.5605	104	7.5	6.57	0.12	20.97	/		
5	13.907	106	7.5	9.52	0.3	44.34	/		
6	13.8915	84	7.5	15.95	0.1	61.73	/		
7	14.0914	89	7.5	13.94	0.22	39.97	/		
8	14.1312	95	7.5	14.88	0.2	47.6	/		
9	13.7511	101	7.5	9.21	0.005	60.84	/		
10	13.6876	30	7.5	2.67	0.005	40.98	/		
11	12.9107	56	7.5	4.54	0.005	61.73	/		
12	12.8823	70	7.5	6.01	0.005	69.3	/		
13	13.0862	46	7.5	4.97	0.005	100.71	/		
14	12.8665	36	7.5	6.69	0.005	89.06	/		
15	12.9927	49	7.5	10.16	0.005	69.01	/		
16	13.1328	58	7.5	11.28	0.01	45.78	/		
17	12.9851	58	7.5	11.74	0.005	25.98	/		
18	13.0569	54	7.5	7.78	0.005	22.67	/		
19	12.9716	70	7.5	10.37	0.005	34.11	/		
20	13.0101	48	7.5	8.29	0.005	18.09	/		
21	13.4366	48	7.5	5.41	0.005	0	/		
22	13.6741	61	7.5	9.3	0.005	0	/		
23	13.5909	62	7.5	10.38	0.005	0	/		
24	13.3223	82	7.5	11.45	0.06	0	/		
25	13.1293	68	7.5	8.25	0.005	0	/		
26	13.0805	52	7.5	10.76	0.005	0	/		
27	12.9282	74	7.5	12.62	0.29	18.98	/		
28	12.9675	82	7.5	12.48	0.37	8.83	/		
29	13.136	69	7.5	13.88	0.01	28.51	/		
30	13.2812	58	7.5	9.87	0.005	16.32	/		
31	13.168	35	7.5	7.53	0.02	30.4	/		
合计 (或加权 平均)	411.434	70.2	7.5	10.1	0.075	1108.02	/	694382	

中山市珍家山污水处理有限公司运行情况记录表

2022年9月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	6.0651	/	/	/	/	36.64	/	627876	注：1、cod、氨氮进出水浓度均为企业自测数据；2、2022年9月1日11时至9月4日8时因配合扩建工程需要，停产69小时，2022年9月12日7时至9月13日10时因停电停产27小时，总共停产96小时
2	0	/	/	/	/	10.5	/		
3	0	/	/	/	/	35.8	/		
4	7.024	81	7.5	13.47	0.17	15.82	/		
5	10.8156	57	7.5	11.51	0.09	0	/		
6	10.726	59	7.5	13.29	0.04	0	/		
7	11.4916	94	7.5	11.44	0.06	47.31	/		
8	11.9044	77	7.5	14.26	0.005	45.45	/		
9	12.2532	98	7.5	13.19	0.34	71.43	/		
10	13.1848	86	7.5	14.65	0.18	22.02	/		
11	13.2908	74	7.5	15.48	0.01	36.55	/		
12	3.5986	/	/	/	/	31.11	/		
13	6.6219	98	7.5	15.6	0.12	0	/		
14	12.8723	80	7.5	13.25	0.22	26.44	/		
15	11.9898	99	7.5	17.47	0.005	26.73	/		
16	13.0362	74	7.5	15.38	0.005	0	/		
17	12.9531	95	7.5	19.3	0.005	0	/		
18	13.2864	94	7.5	19.56	0.005	0	/		
19	13.3568	56	7.5	7.96	0.005	0	/		
20	13.524	62	7.5	10.26	0.005	0	/		
21	13.383	102	7.5	13.96	0.005	0	/		
22	13.1034	61	7.5	13.53	0.005	0	/		
23	13.0981	70	7.5	16.55	0.005	47.18	/		
24	12.1129	68	7.5	16.02	0.005	62.07	/		
25	11.5982	67	7.5	13.16	0.005	50.42	/		
26	12.2184	73	7.5	13.92	0.005	0	/		
27	12.3476	61	7.5	17.45	0.005	0	/		
28	11.6023	78	7.5	16.87	0.005	0	/		
29	11.238	85	7.5	19.16	0.005	19.46	/		
30	12.6246	47	7.5	6.76	0.005	40.04	/		
/	/	/	/	/	/	/	/		
合计 (或加权平均)	321.321	76.4	7.5	14.3	0.047	624.97	/	627876	

中山市珍家山污水处理有限公司运行情况记录表

2022年10月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	11.9159	38	7.5	7.84	0.01	0.00	/	861091	注：cod、氨氮进出水浓度均为企业自测数据；
2	11.2313	44	7.5	10.98	0.16	0.00	/		
3	11.3400	54	7.5	12.55	0.01	0.00	/		
4	11.6027	61	7.5	12.58	0.09	0.00	/		
5	11.5804	94	7.5	14.10	0.03	0.00	/		
6	11.6767	88	7.5	15.87	0.01	0.00	/		
7	11.5878	68	7.5	10.10	0.01	0.00	/		
8	10.4113	78	7.5	15.78	0.01	0.00	/		
9	10.3594	66	7.5	13.83	0.21	0.00	/		
10	12.5472	76	7.5	15.10	0.18	0.00	/		
11	12.4614	61	7.5	15.13	0.03	0.00	/		
12	14.4750	77	7.5	16.92	0.38	0.00	/		
13	13.4431	78	7.5	14.02	0.03	0.00	/		
14	13.0168	68	7.5	17.97	0.13	0.00	/		
15	13.5176	85	7.5	14.61	0.13	0.00	/		
16	13.6529	72	7.5	14.56	0.02	0.00	/		
17	12.8148	93	7.5	16.18	0.03	0.00	/		
18	12.9008	87	7.5	16.73	0.01	0.00	/		
19	11.9512	78	7.5	14.85	0.04	37.13	/		
20	13.2661	85	7.5	18.57	0.01	48.77	/		
21	13.0838	79	7.5	17.46	0.15	50.66	/		
22	13.4902	65	7.5	17.76	0.01	51.64	/		
23	13.2079	82	7.5	17.58	0.01	51.12	/		
24	12.8971	72	7.5	19.30	0.01	49.81	/		
25	12.8980	82	7.5	19.24	0.17	49.03	/		
26	13.1621	78	7.5	19.30	1.42	50.92	/		
27	13.6173	74	7.5	17.87	1.71	52.95	/		
28	12.8603	80	7.5	18.44	0.89	51.38	/		
29	11.3121	82	7.5	21.24	0.33	50.34	/		
30	10.8541	86	7.5	20.06	0.01	49.75	/		
31	11.0397	74	7.5	20.89	0.03	49.22	/		
合计 (或加权平均)	384.1750	75	8	16.11	0.21	642.72	/	861091	

中山市珍家山污水处理有限公司运行情况记录表

2022年11月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.5994	135	7.5	21.56	0.03	44.4	/	927213	注：cod、氨氮进出水浓度均为企业自测数据；
2	10.4293	78	7.5	17.26	0.3	42.34	/		
3	9.4835	73	7.5	10.43	0.63	36.68	/		
4	9.8834	56	7.5	8.52	0.51	40.86	/		
5	10.7041	103	7.5	14.74	0.19	44.3	/		
6	11.2003	64	7.5	12.31	0.03	43.19	/		
7	10.9409	54	7.5	8.97	0.53	40.6	/		
8	15.2926	24	7.5	6.18	0.26	43.08	/		
9	15.2805	22	7.5	9.8	0.77	42.76	/		
10	14.9707	80	7.5	12.16	1.04	45.14	/		
11	14.0316	162	7.5	15.84	1.1	43.13	/		
12	13.8141	78	7.5	16.77	0.7	31.66	/		
13	14.681	117	7.5	18.07	1.99	39.06	/		
14	15.3688	140	7.5	17.07	3.06	41.34	/		
15	15.4631	145	7.5	18.28	1.35	39.8	/		
16	16.5868	146	7.5	19.12	0.2	44.82	/		
17	17.1291	145	7.5	21.16	0.22	44.98	/		
18	17.4382	108	7.5	22.88	0.52	26.48	/		
19	16.8614	120	7.5	21.59	1.5	45.04	/		
20	15.8624	154	7.5	21.17	2.22	43.82	/		
21	15.9922	160	7.5	21.38	2.53	41.34	/		
22	16.0348	94	7.5	17.25	1.44	34.52	/		
23	16.4418	76	7.5	12.04	0.79	38.69	/		
24	14.0628	78	7.5	9.92	0.24	40.6	/		
25	15.0791	70	7.5	12.18	0.06	41.18	/		
26	15.188	56	7.5	15.13	0.04	39.43	/		
27	16.3579	53	7.5	16.83	0.01	40.54	/		
28	16.517	77	7.5	14.96	0.005	25.69	/		
29	16.1425	70	7.5	18.34	0.01	38.27	/		
30	15.7694	78	7.5	17.87	0.03	37.21	/		
/	/	/	/	/	/	/	/		
合计(或加权平均)	433.6067	95	8	15.97	0.77	1200.97	/	927213	

中山市珍家山污水处理有限公司运行情况记录表

2022年12月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	16.4475	90	7.5	14.71	0.05	20.16	/	968208	注：cod、氨氮进出水浓度均为企业自测数据；2022年12月14日6时至8时和2022年12月15日15时至2022年12月16日6时，因广东电网提供新接点供我司接驳取电以及岐江道工程配合对我司新排放口的尾水管道进行接驳切换，停产17小时。
2	16.6821	90	7.5	19.57	0.005	34.25	/		
3	15.4624	82	7.5	14.18	0.02	34.58	/		
4	16.0156	120	7.5	21.23	0.03	34.15	/		
5	15.7854	77	7.5	16.29	0.005	10.68	/		
6	16.0785	122	7.5	19.98	0.005	32.76	/		
7	17.0978	88	7.5	20.21	0.11	33.91	/		
8	15.1671	121	7.5	18.11	0.39	28.07	/		
9	15.7098	125	7.5	22.38	0.005	32.76	/		
10	15.5131	101	7.5	18.95	0.005	5.51	/		
11	15.1894	92	7.5	15.89	0.005	19.97	/		
12	15.5801	98	7.5	17.86	0.02	29.17	/		
13	14.1695	141	7.5	22.18	0.31	21.94	/		
14	9.0835	106	7.5	21.39	0.09	0	/		
15	6.2786	52	7.5	16.14	0.42	0	/		
16	9.1677	91	7.5	14.59	0.24	6.04	/		
17	14.6468	108	7.5	20.29	0.02	10.11	/		
18	14.6349	198	7.5	17.44	0.04	7.23	/		
19	14.778	269	7.5	17.72	0.37	0	/		
20	14.6217	168	7.5	19.94	1.1	26.73	/		
21	14.5001	100	7.5	20.5	1.23	12.69	/		
22	15.2709	86	7.5	18.14	1.08	34.39	/		
23	16.4796	106	7.5	18.59	0.78	30.32	/		
24	16.8192	81	7.5	17.68	0.6	54.79	/		
25	16.5379	170	7.5	17.77	0.69	27.4	/		
26	16.0499	259	7.5	19.26	0.62	30.65	/		
27	16.0684	99	7.5	17.88	1.87	51.63	/		
28	13.7299	540	7.5	14.87	1.43	64.85	/		
29	15.0929	123	7.5	15.88	0.05	63.32	/		
30	16.7683	167	7.5	16.08	0.03	64.42	/		
31	15.4875	116	7.5	20.12	0.04	67.06	/		
合计(或加权平均)	460.914	136	8	18.3	0.38	889.54	/	968208	